

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

RECEIVED
MAR 26 1969

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

SALEM, OREGON

State Well No. 26/1521-22

State Permit No.

(1) OWNER:

Name

Address

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☐

16" Diam. from 0 ft. to 20 ft. Gage 1/4"

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☐ No.

Type of perforator used

Size of perforations

in. by

in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name

Type

Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 20 ft. below land surface Date

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller

Yield: 1200 gal./min. with 40 ft. drawdown after 4 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 60 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE

Depth of seal 18 ft.

Diameter of well bore to bottom of seal 20 in.

Were any loose strata cemented off? ☐ Yes ☒ No DepthWas a drive shoe used? ☐ Yes ☒ NoDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County LAKE

Driller's well number 2

NE 1/4 NE 1/4 Section 21 T. 26 R. 15 W.M.

Bearing and distance from section or subdivision corner

75' SW MORE HOUSE CORNER

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 502 ft. Depth of completed well 502 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
DIRT SANDY CLAY	0	10	20
CLAY WHITE	10	60	
BLACK SAND	60	100	
Blue CLAY	100	120	
Water sand (CONGLOM)	120	128	
Red CLAY	128	170	
Black sand	170	220	
Red CLAY	220	320	
Boulders Round Rolling	320	360	
BLACK SAND	360	400	
Blue CLAY	400	450	
300 gal water test @	450	470	
SAND WHITE CRISTAL	470	508	
(MIX) BLACK SANDS			
Volcanic Black Rock	485	508	

Work started May 20 68 Completed March 9 19

Date well drilling machine moved off of well March 27 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Harold W. Soule Date March 14, 1969

(Drilling Machine Operator)

Drilling Machine Operator's License No. 509

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harold W. Soule, Harold W. Soule

(Person, firm or corporation)

(Type or print)

Address FORT ROCK OREGON

[Signed] Harold W. Soule

(Water Well Contractor)

Contractor's License No. 475 Date March 14, 1969