

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

State Well No.

State Permit No.

APR 12 1978

26515E-24d
G-8134

(1) OWNER:

Name Cody J. Porterfield

Address FT. ROCK, OR. 97735

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Casing Undisturbed
Threaded ☐ Welded ☐

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☐ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 52' Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used SEAL UNDISTURBED

Well sealed from land surface to ft.

Diameter of well bore to bottom of seal in.

Diameter of well bore below seal in.

Number of sacks of cement used in well seal sacks

How was cement grout placed?

Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

WATER RESOURCES DEPT.

(10) LOCATION OF WELL:

County LAKE

Driller's well number

CENTER SE 1/4 Section 24 T. 26S R. 15E W.M.

Bearing and distance from section or subdivision corner 1320 N + 1320 W of SE CORNER SEC 24

(11) WATER LEVEL: Completed well.

Depth at which water was first found 24 ft.

Static level 18 ft. below land surface. Date

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 975 ft. Depth of completed well 975 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
GRN CLAY	700	710	
GRAY SAND FINE MED WB	710	758	
GRN CLAY	758	770	
GRAY SAND Pumice WB	770	855	
TAN CLAY	855	899	
BLK SAND FINE Pumice	899	915	
HD BLK CLAY	915	953	
BLK SAND + CLAYERS + Pumice	953	958	
HD BLK ROCK	958	972	
BLK SAND Pumice. WB	972	975	

Work started 3-27 1978 Completed 3-31 1978

Date well drilling machine moved off of well 4-3 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William D. Williams Date 4-3, 1978
(Drilling Machine Operator)

Drilling Machine Operator's License No. 864

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name William D. Williams
(Person, firm or corporation) (Type or print)

Address 3220 N. Oak St., Redmond, Or. 97756

[Signed] William D. Williams
(Water Well Contractor)

Contractor's License No. 665 Date 4-3, 1978