

RECEIVED

Lake 4419

275/14E-33 66

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

JUN 17 1988

PLEASE TYPE or PRINT IN INK

(for official use only)

WATER RESOURCES DEPT

(1) OWNER: SALEM, OREGON Name: Chuck & Elsie Edwards Address: Hedaout Road Box 71 City: Silver Lake State: Oregon

(10) LOCATION OF WELL by legal description: County: Lake N 1/4 N 1/4 of Section 33 Township: 27S Range: 14E, WM. Tax Lot: Lot: Block: Subdivision:

(2) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

MAILING ADDRESS OF WELL (or nearest address): 38165 Baspage Ln Springfield Oregon 97478

(3) TYPE OF WELL: Rotary Air [] Driven [] Domestic [] Industrial [] Municipal [] Rotary Mud [] Dug [] Irrigation [X] Thermal: Withdrawal [] ReInjection [] Cable [X] Bored [] Piezometric [] Grounding [] Test []

(11) WATER LEVEL of COMPLETED WELL: Depth at which water was first found: 480 ft. Static level: 28 ft. below land surface. Date: Feb-88 Artesian pressure: lbs. per square inch. Date:

(4) PROPOSED USE (check): Steel Threaded [X] Plastic Welded [X] 14" Diam. from 24 ft. to 22 ft. Gauge: .25

(12) WELL LOG: Diameter of well below casing: 14 ft. Depth drilled: 490 ft. Depth of completed well: 490 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

LINER INSTALLED: Steel Threaded [] Plastic Welded []

Table with columns: MATERIAL, From, To, SWL. Rows include: Top Soil (0-1), Rock Hole (LAVA) (1-120), SAND STONE (BROWN) (120-205), ROCK (HARD) (205-240), Clay (240-440), ROCK HARD (440-473), GRAVEL & SAND (BINDER) (473-490)

(6) PERFORATIONS: Perforated? [] Yes [X] No in. Size of perforations in. perforations from ft. to ft.

(7) SCREENS: Well screen installed? [] Yes [X] No Manufacturer's Name: Type: Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made? [] Yes [X] No If yes, by whom? Air test gal./min. with drill stem at ft. hrs. Bailer test 30 gal./min. with 0 ft. drawdown after 1 hrs. Artesian flow g.p.m. Temperature of water 51 Depth artesian flow encountered ft.

Date work started 11-23-87 / completed 6-1-88 Date well drilling machine moved off of well 6-1-88 19

(9) CONSTRUCTION: Special standards: Yes [] No [X] Well seal—Material used: Cement Well sealed from land surface to 19 ft. Diameter of well bore to bottom of seal 18 in. Diameter of well bore below seal 14 in. Amount of sealing material 2.2 sacks [X] pounds [] How was cement grout placed? pumped

(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Walter K Baert Date 6-15-88

Was pump installed? NO Type HP Depth ft. Was a drive shoe used? [] Yes [X] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(bonded) Water Well Constructor Certification: Bond SB 468 48 Issued by: Oregon Auto Ins. (Surety Company Name) On behalf of WALTER K. BAEKT (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. [Signed] Walter K Baert (Water Well Constructor) (Dated) 6-15-88

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690