NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be

filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

## WATER WELL RED

(Please type or print)

(Do not write above this TR RESOURCES DEPT.

	SALEM, OREGON
(1) OWNER:	(10) LOCATION OF WELL:
Name C. F. Enloe	County Lake Driller's well number
Address Rte. 6, Box 147	SW 1/4 1/4 Section 26 T. 385 R. 19E1 W.M.
Lakeview, Oregon 97630	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well  ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 6 ft.
Rotary X Driven Domestic Industrial Municipal I	Static level 21 ft. below land surface. Date
Cable ☐ Jetted ☐ ☐ ☐ Irrigation ☐ Test Well ☐ Other ☐	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded  Welded  On the control of the control	(12) WELL LOG: Diameter of well below casing  The perth drilled 549 ft. Depth of completed well 540 ft.
16 "Diam from 0 ft to 540 ft Gage .250	Depart times 5.10 In. September 5.10
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? X Yes \( \square\) No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Factory	MATERIAL From To SWL
Size of perforations 1/8 in. by 2½ in.	Hard pan 0 14 6'
16,000 perforations from 40 ft. to 540 ft.	Yellow Clay 14 40'
perforations fromft. toft.	Small sand & gravel
perforations fromft. toft.	streaks between clay
(7) SCREENS.	stratis 40 540*
(7) SCREENS: Well screen installed? ☐ Yes 🛪☐ No	
Manufacturer's Name  Type	
Diam. Slot size Set from ft. to ft.	All alluvial fill sandy clays and gravel
Diam. Slot size Set from ft. to ft.	streaks (very small)
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? X Yes No If yes, by wrons tate	
Yield: /900 gal./min. with /3 ft. drawdown after 55 hrs.	
Yield: ///// gal./min. with // it. drawdown arter 23 lis.	9 1. 1 12 1. 12 E
	7 4
H 4 H H	A CONTRACT OF THE CONTRACT OF
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	Work started 3/28 1978 Completed 6/1 1978
perature of water Depth artesian flow encountered ft.	Work started 3/28 1978 Completed 6/1 1978  Date well drilling machine moved off of well 19
(9) CONSTRUCTION:	и
Well seal—Material used Cement grout  Well sealed from land surface to 22 ft.  Diameter of well hore to bottom of seal 32 in.	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal 24 in.	[Signed] (Drilling Machine Operator)  316
Number of sacks of cement used in well seal 14 Yds sacks,	Drilling Machine Operator's License No. 316
Number of sacks of bentonite used in well seal sacks	
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of waterlbs./100 gals.  Was a drive shoe used?   Yes No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name C & C. Enloe Drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address P.O. Box 323, Dorris, Ca. 96023
Method of sealing strata off	[Signed] Carl D. Elle
Was well gravel packed? ☐ Yes ☐ No Size of gravel: _3./8_3./4	(Water Well Contractor)
Gravel placed from	Contractor's License No. 503 Date 6/5 , 19.78