

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED MAR 31 1969

WATER WELL REPORT

RECEIVED APR 9 1969

Lake 490

STATE ENGINEER, SALEM, OREGON, 97310

within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print) (Do not write above this line)

STATE ENGINEER SALEM OREGON

State Well No. 26/15-34(N)

State Permit No.

(1) OWNER:

Name Marrit Parks
Address RT 2 Box 784 Oregon City Ore

(2) TYPE OF WORK (check):
New Well [] Deepening [x] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []

CASING INSTALLED:

16" Diam. from 0 ft. to 20 ft. Gage 1/4
20" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [] Yes [x] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 21 ft. below land surface Date 3/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom? Goeres
Yield: 1850 gal./min. with 11 ft. drawdown after 4 hrs.

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 60 Was a chemical analysis made? [] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used ? Old Well
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [] Yes [x] No
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lake Driller's well number Parks 1
1/4 1/4 Section 34 T. 26 S R. 15 E W.M.

Bearing and distance from section or subdivision corner 20 ft from SW corner of sec

(12) WELL LOG:

Diameter of well below casing 16"-70"
Depth drilled 175 ft. Depth of completed well 175 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: Original 16 in casing, Broken lava soft dark 10% silty, gravel fine soft dark, Broken lava soft dark some clinkers 10% a loss.

Lost cutting when drilled
solid rock fast drill rate water all the way at about 10 ft intervals

Work started Jan 19 69 Completed Feb 30 19 69
Date well drilling machine moved off of well March 19 69

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Gordon Goeres March 20 69 (Drilling Machine Operator)

Drilling Machine Operator's License No. 305

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Gordon Goeres (Person, firm or corporation) (Type or print)
Address Silver Lake Ore
[Signed] Gordon Goeres (Water Well Contractor)

Contractor's License No. 136 Date , 19

Water Level Record

OWNER: My PARKS - Leased To Beley OWNER'S NO. # 3

Description of measuring point: Top of casing on NE side of well.

Date	Water Level Feet (above) (below) Land Surface	Remarks	Date	Water Level Feet (above) (below) Land Surface	Remarks
8/28/56	21.94	WSB			
8/20/57	21.90	WSB			
10/24/57	21.24	WSB			
4-27-58	24.30	WSB			
10-14-58	23.54	WSB			
5-12-59	66	Pump operating			
15					
10-15-59	22.17	WSB			
4-27-60	21.15	JES-WSB			
5-3-61	21.05	WSB			
10-17-61	WET TAPE	PUMPING WSB RD			

REMARKS: _____

