NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED FEB 19 1980 WATER RESOURCES DEPT SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED OCT 22 1979 WATER RESOURCES DEPT SALEM, OREGON

State Well No. 26S/16E -6
State Permit No. Lake 497

(1) OWNER:
Name ~~Lyle Adams~~ C. Wade Brown
Address 61690 Pettigrew Bend Oregon 97701

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Auger ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☑ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
16" Diam. from 0 ft. to 18 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 900 gal./min. with ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? pressure grout
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lake Driller's well number 68
NW ¼ SE ¼ Section 6 T. 26S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 550 ft.
Static level 96 ft. below land surface. Date Sept 27
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 16" to 180'-8"
Depth drilled 629 ft. Depth of completed well 629 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sand gravel cobbles	0	9	
Grey Brown conglomerate hard rock.	9	310	
med Grey rock	310	335	
Grey hard rock	335	416	
Grey brown med hard with boulders.	416	454	
Grey hard rock	454	485	
Grey hard rock (broken)	485	515	
Med hard	515	524	
Grey hard	524	550	
Grey + Brown hard, broken water bearing	550	622	96
Grey Hard basalt soft	622	629	

Work started Sept 19 1979 Completed Sept 27 1979
Date well drilling machine moved off of well Sept 27 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Lyle Adams (Drilling Machine Operator) Date Sept 28, 1979.
Drilling Machine Operator's License No. 1292

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Lyle Adams (Person, firm or corporation) (Type or print)
Address RT 3 Box 122 X Hillsboro Oregon 97123
[Signed] Lyle Adams (Water Well Contractor)
Contractor's License No. 690 Date Sept 28, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119