

# LAKE 52368

Well #6

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(ORS 537.765 & OAR 690-205-0210)

LAKE 52308  
LAKE 52368  
Well #11 #2  
Am Taped

L 137024

WELL LABEL # L ~~10-3847~~ TAG LOST!  
START CARD # 206439  
ORIGINAL LOG #

Instructions for completing this report are on the last page of this form.

(1) LANDOWNER Owner Well I.D.  
First Name Thomas Last Name McDaniel  
Company  
Address PO Box 87  
City Summer Lake State OR Zip 97140

(2) TYPE OF WORK  New  Conversion  Deepening  
 Alteration (complete Sections 2a & 10)  Abandonment (complete Section 5a)

(2a) PRE-ALTERATION: Well Depth \_\_\_\_\_ ft.  
Seal Material \_\_\_\_\_  
Casing Type:  Steel  Plastic  Other \_\_\_\_\_  
Casing Gauge \_\_\_\_\_ Casing Diameter \_\_\_\_\_

(3) DRILL METHOD  Rotary Air  Rotary Mud  Auger  
 Cable  Cable Mud  Reverse Rotary  Other \_\_\_\_\_

(4) PROPOSED USE  Domestic  Irrigation  Community  
 Industrial/Commercial  Livestock  Dewatering  Injection  
 Thermal  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION  
Depth of Completed Well 260 ft Special Standard:  Yes (attach copy)

BORE HOLE				SEAL			
Dia	From	To	Material	From	To	Amount	Scks/lbs
24"	0	39	Cement	0	39	80	5CK
24"	39	210	Cement	210	210	750	5CK
12"	210	260					

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft to \_\_\_\_\_ ft Material \_\_\_\_\_  
Filter pack from \_\_\_\_\_ ft to \_\_\_\_\_ ft Material \_\_\_\_\_ Size \_\_\_\_\_

(5a) ABANDONMENT USING UNHYDRATED BENTONITE:  
Calculated Amount Proposed to be Used: \_\_\_\_\_ sacks/lbs  
Actual Amount Used: \_\_\_\_\_ sacks/lbs

(6) CASING/LINER

Csg/Linr	Dia	From	To	Gauge	Steel	Plastic	Welded	Thrd
X	16"	0	39	.250	X		X	
X	12"	3	210	.750	X		X	

Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_  
Temporary casing  Yes Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

(7) PERFORATIONS/SCREENS  
Perforations Method \_\_\_\_\_  
Screens Type \_\_\_\_\_ Material \_\_\_\_\_

Perf	Scrm	Csng	Linr	Screen Dia	From	To	Screen/slot width	Slot length	# of slots	Tele/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian  
Yield gal/min \_\_\_\_\_ Drawdown \_\_\_\_\_ Drill stem/Pump depth \_\_\_\_\_ Duration (hr) \_\_\_\_\_  
Temperature 60 °F Lab analysis  Yes By \_\_\_\_\_  
Water quality concerns?  Yes (describe below) TDS \_\_\_\_\_ ppm

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)  
County LAKE Twp 30 N or S Range 17 E or W W.M.  
Sec 5 NW 1/4 1/4 of the \_\_\_\_\_ 1/4 Tax Lot 600  
Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_  
Lat \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD  
Long \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD

Street Address of Well (or nearest address) 48413 DESSERT SPRING RD SUMMER LAKE OR 97140

(10) STATIC WATER LEVEL

Existing Well/Pre-Alteration	Date	SWL (psi)	+	SWL (ft)
Completed Well	<u>10-24-10</u>	<u>2.75</u>		

Flowing Artesian?  Yes Dry Hole?  Yes  
WATER BEARING ZONES Depth water was first found 23'

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)
	<u>20</u>	<u>25</u>	<u>25gal</u>			

(11) WELL LOG Ground Elevation \_\_\_\_\_

Material	From	To
TOP SOIL	0	6
Black Clay	6	10
Grey Clay	10	120
Blue Clay	120	180
Grey Basalt	180	225
Red Sider	225	260

RECEIVED RECEIVED BY OWRD  
MAR 13 2012 JUL 12 2012  
WATER RESOURCES DEPT SALEM, OREGON SALEM, OR

Date Started 9-28-10 Completed 10-28-10

(unbonded) Water Well Constructor Certification  
I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

License Number \_\_\_\_\_ Date \_\_\_\_\_  
Signed \_\_\_\_\_

(bonded) Water Well Constructor Certification  
I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1654 Date 10-12-11  
Signed Tom Search  
Contact Info (optional)  
Search Drilling INC  
70M Search 501-576-2189

ORIGINAL - WATER RESOURCES DEPARTMENT ONE COPY FOR CONSTRUCTOR ONE COPY FOR **RECEIVED BY OWRD**  
SUBMITTED TO THE WATER RESOURCES DEPARTMENT WITHIN 30 DAYS OF COMPLETION OF WORK 01/02/2009

APR 24 2014

SALEM, OR

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(ORS 537.765 & OAR 690-205-0210)

LAKE well #12  
52368 LAKE 52368  
Am Taped

L 137024

WELL LABEL # L 103897 TAG LOST!  
START CARD # 206439  
ORIGINAL LOG #

**DRAFT**

Instructions for completing this report are on the last page of this form.

(1) LANDOWNER Owner Well I.D.  
First Name Thomas Last Name McDaniel  
Company \_\_\_\_\_  
Address PO Box 87  
City Summer Lake State OR Zip 97640

(2) TYPE OF WORK  New  Conversion  Deepening  
 Alteration (complete Sections 2a & 10)  Abandonment (complete Section 5a)

(2a) PRE-ALTERATION: Well Depth \_\_\_\_\_ ft.  
Seal Material \_\_\_\_\_  
Casing Type:  Steel  Plastic  Other \_\_\_\_\_  
Casing Gauge \_\_\_\_\_ Casing Diameter \_\_\_\_\_

(3) DRILL METHOD  Rotary Air  Rotary Mud  Auger  
 Cable  Cable Mud  Reverse Rotary  Other \_\_\_\_\_

(4) PROPOSED USE  Domestic  Irrigation  Community  
 Industrial/Commercial  Livestock  Dewatering  Injection  
 Thermal  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION  
Depth of Completed Well 260 ft. Special Standard:  Yes (attach copy)

BORE HOLE			SEAL				
Dia	From	To	Material	From	To	Amount	Scks/lbs
24"	0	39	Cement	0	39	80	SCK
18"	39	210	Cement	40	210	150	SCK
12"	210	260					

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Filter pack from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_ Size \_\_\_\_\_

(5a) ABANDONMENT USING UNHYDRATED BENTONITE:  
Calculated Amount Proposed to be Used: \_\_\_\_\_ sacks/lbs  
Actual Amount Used: \_\_\_\_\_ sacks/lbs

(6) CASING/LINER

Csg/Linr	Dia	+	From	To	Gauge	Steel	Plastic	Welded	Thrd
X	16"	+	1	39	.250	X		X	
X	12"	-	3	220	.250	X		X	

Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_  
Temporary casing  Yes Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

(7) PERFORATIONS/SCREENS  
Perforations Method \_\_\_\_\_  
Screens Type \_\_\_\_\_ Material \_\_\_\_\_

Perf	Scrn	Csg/Linr	Screen Dia	From	To	Screen/slot width	Slot length	# of slots	Tele/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailer  Air  Flowing Artesian  
Yield gal/min 1000. Drawdown \_\_\_\_\_ Drill stem/Pump depth 260 Duration (hr) \_\_\_\_\_  
Temperature 60 °F Lab analysis  Yes By \_\_\_\_\_  
Water quality concerns?  Yes (describe below) TDS \_\_\_\_\_ ppm

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)  
County Lake Twp 30 N or S Range 17 E or W W.M.  
Sec 5 NW NW 1/4 of the \_\_\_\_\_ 1/4 Tax Lot 600  
Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_  
Lat \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD  
Long \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD

Street Address of Well (or nearest address) 48413 Dessert Spring Rd Summer Lake OR 97640

(10) STATIC WATER LEVEL

	Date	SWL (psi)	+	SWL (ft)
Existing Well/Pre-Alteration	<u>10-24-10</u>	<u>2 PSI</u>		
Completed Well				

Flowing Artesian?  Yes Dry Hole?  Yes  
WATER BEARING ZONES Depth water was first found 23'

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)
	<u>20</u>	<u>25</u>	<u>25 gal</u>			

(11) WELL LOG Ground Elevation \_\_\_\_\_

Material	From	To
TOP SOIL	0	2
Black Clay	2	60
Gray Clay	60	120
Blue Clay	120	180
Gray Basalt	180	225
Red Cider	225	260

Date Started 9-28-10 Completed 10-28-10

(unbonded) Water Well Constructor Certification  
I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.  
License Number \_\_\_\_\_ Date \_\_\_\_\_  
Signed \_\_\_\_\_

(bonded) Water Well Constructor Certification  
I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
License Number 1654 Date 10-12-11  
Signed [Signature]  
Contact Info. (optional)  
Search Drilling INC  
70M Search 501-576-2189

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(ORS 537.765 & OAR 690-205-0210)

*Well #12*  
**LAKE 52368**  
*Amended*

LAKE 52368 L 137024

WELL LABEL # ~~L 103897~~ TAG LOST!  
START CARD # ~~306439~~  
ORIGINAL LOG #

**DRAFT**

Instructions for completing this report are on the last page of this form.

**(1) LANDOWNER**

Owner Well I.D.

First Name Thomas Last Name SEARCH MC DONALD  
Company \_\_\_\_\_  
Address PO Box 87  
City Summer Lake State OR Zip 97640

**(2) TYPE OF WORK**

New  Conversion  Deepening  
 Alteration (complete Sections 2a & 10)  Abandonment (complete Section 5a)

**(2a) PRE-ALTERATION:**

Well Depth \_\_\_\_\_ ft.

Seal Material \_\_\_\_\_

Casing Type:  Steel  Plastic  Other \_\_\_\_\_

Casing Gauge \_\_\_\_\_ Casing Diameter \_\_\_\_\_

**(3) DRILL METHOD**

Rotary Air  Rotary Mud  Auger  
 Cable  Cable Mud  Reverse Rotary  Other \_\_\_\_\_

**(4) PROPOSED USE**

Domestic  Irrigation  Community  
 Industrial/Commercial  Livestock  Dewatering  Injection  
 Thermal  Other \_\_\_\_\_

**(5) BORE HOLE CONSTRUCTION**

Depth of Completed Well \_\_\_\_\_ ft. Special Standard:  Yes (attach copy)

BORE HOLE			SEAL				
Dia	From	To	Material	From	To	Amount	Scks/lbs
24"	0	39	Cement	0	39	80	5CK
18"	39	210	Cement	40	210	150	5CK
12"	210	260					

How was seal placed: Method  A  B  C  D  E

Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_

Filter pack from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_ Size \_\_\_\_\_

**(5a) ABANDONMENT USING UNHYDRATED BENTONITE:**

Calculated Amount Proposed to be Used: \_\_\_\_\_ sacks/lbs

Actual Amount Used: \_\_\_\_\_ sacks/lbs

**(6) CASING/LINER**

Csng/Linr	Dia	+	From	To	Gauge	Steel	Plastic	Welded	Thrd
X	16"	+	0	39	.250	Y		Y	
Y	12"	-	3	220	.750	Y		Y	

Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_

Temporary casing  Yes Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

**(7) PERFORATIONS/SCREENS**

Perforations Method \_\_\_\_\_

Screens Type \_\_\_\_\_ Material \_\_\_\_\_

Perf	Scrn	Csng	Linr	Screen Dia	From	To	Screen/slot width	Slot length	# of slots	Tele/pipe size

**(8) WELL TESTS: Minimum testing time is 1 hour**

Pump  Bailer  Air  Flowing Artesian

Yield gal/min \_\_\_\_\_ Drawdown \_\_\_\_\_ Drill stem/Pump depth \_\_\_\_\_ Duration (hr) \_\_\_\_\_

Temperature 60 °F Lab analysis  Yes By \_\_\_\_\_

Water quality concerns?  Yes (describe below) TDS \_\_\_\_\_ ppm

From	To	Description	Amount	Units

**(9) LOCATION OF WELL (legal description)**

County Lake Twp 30 N or S Range 17 E or W W.M.

Sec 5 1/2 NW 1/4 of the \_\_\_\_\_ 1/4 Tax Lot 600

Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_

Lat \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD

Long \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD

Street Address of Well (or nearest address) 48413 Dessert

Spring RD Summer Lake OR 97640

**(10) STATIC WATER LEVEL**

	Date	SWL (psi)	+	SWL (ft)
Existing Well/Pre-Alteration	10-28-10	275		
Completed Well				

Flowing Artesian?  Yes Dry Hole?  Yes

**WATER BEARING ZONES**

Depth water was first found \_\_\_\_\_

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)
	20	25	25 gpm			

**(11) WELL LOG**

Ground Elevation \_\_\_\_\_

Material	From	To
TOP SOIL	0	2
BLACK CLAY	2	60
Gray clay	60	120
BLUE CLAY	120	180
gray basalt	180	225
Red CIDER	225	260

Date Started 9-28-10 Completed 10-28-10

**(unbonded) Water Well Constructor Certification**

I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. The data and information reported above are true to the best of my knowledge and belief.

License Number APR 05 2012 Date \_\_\_\_\_

Signed \_\_\_\_\_  
**WATER RESOURCES DEPT**

**(bonded) Water Well Constructor Certification**

I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1654 Date 10-12-11

Signed \_\_\_\_\_

Contact Info. (optional) \_\_\_\_\_

*SEARCH DRILLING INC*  
*TOM SEARCH SUI-976-2189*



STATE OF OREGON  
WATER SUPPLY WELL REPORT

(ORS 537.765 & OAR 690-205-0210)

Well #2  
LAKE 52368

L 137024

WELL LABEL # L ~~103897~~ TAG LOST!

START CARD # 206439

ORIGINAL LOG #

DRAFT

(1) LANDOWNER Owner Well I.D.  
First Name Thomas Last Name Search  
Company \_\_\_\_\_  
Address PO Box 87  
City Summer Lake State OR Zip 97140

(2) TYPE OF WORK  New  Conversion  Deepening  
 Alteration (complete Sections 2a & 10)  Abandonment (complete Section 5a)

(2a) PRE-ALTERATION: Well Depth \_\_\_\_\_ ft.  
Seal Material \_\_\_\_\_  
Casing Type:  Steel  Plastic  Other \_\_\_\_\_  
Casing Gauge \_\_\_\_\_ Casing Diameter \_\_\_\_\_

(3) DRILL METHOD  Rotary Air  Rotary Mud  Auger  
 Cable  Cable Mud  Reverse Rotary  Other \_\_\_\_\_

(4) PROPOSED USE  Domestic  Irrigation  Community  
 Industrial/Commercial  Livestock  Dewatering  Injection  
 Thermal  Other \_\_\_\_\_

(5) BORE HOLE CONSTRUCTION  
Depth of Completed Well \_\_\_\_\_ ft. Special Standard:  Yes (attach copy)

BORE HOLE			SEAL			
Dia	From	To	Material	From	To	Amount Scks/lbs
24"	0	39	Cement	0	39	80 SCK
18"	39	210	Cement	210	210	150 SCK
12"	210	260				

How was seal placed: Method  A  B  C  D  E  
 Other \_\_\_\_\_  
Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
filter pack from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_ Size \_\_\_\_\_

(5a) ABANDONMENT USING UNHYDRATED BENTONITE:  
Calculated Amount Proposed to be Used: \_\_\_\_\_ sacks/lbs  
Actual Amount Used: \_\_\_\_\_ sacks/lbs

(6) CASING/LINER

Casing	Linr	Dia	+	From	To	Gauge	Steel	Plastic	Welded	Thrd
X		16"	+	0	39	.250	X			
Y		12"	-	3	210	.750	X			X

Shoe  Inside  Outside  Other Location of shoe(s) \_\_\_\_\_  
Temporary casing  Yes Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_

(7) PERFORATIONS/SCREENS

Perf	Screen	Casing	Linr	Screen Dia	From	To	Screen/slot width	Slot length	# of slots	Tele/pipe size

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian  
Yield gal/min \_\_\_\_\_ Drawdown \_\_\_\_\_ Drill stem/Pump depth \_\_\_\_\_ Duration (hr) \_\_\_\_\_  
Temperature 60° °F Lab analysis  Yes By \_\_\_\_\_  
Water quality concerns?  Yes (describe below) TDS \_\_\_\_\_ ppm

From	To	Description	Amount	Units

(9) LOCATION OF WELL (legal description)  
County Lake Twp 30 N or S Range 17 E or W W.M.  
Sec 5 NW NW 1/4 of the \_\_\_\_\_ 1/4 Tax Lot: 600  
Tax Map Number \_\_\_\_\_ Lot \_\_\_\_\_  
Lat \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD  
Long \_\_\_\_\_ " or \_\_\_\_\_ DMS or DD  
Street Address of Well (or nearest address) 48413 Dessert Spring Rd Summer Lake OR 97140

(10) STATIC WATER LEVEL

	Date	SWL (psi)	+	SWL (ft)
Existing Well/Pre-Alteration	<u>10-24-10</u>	<u>2 PSI</u>		
Completed Well				

Flowing Artesian?  Yes Dry Hole?  Yes

WATER BEARING ZONES Depth water was first found \_\_\_\_\_

SWL Date	From	To	Est Flow	SWL (psi)	+	SWL (ft)
	<u>20</u>	<u>25</u>	<u>25 gal</u>			

(11) WELL LOG Ground Elevation \_\_\_\_\_

Material	From	To
TOP SOIL	0	2
Black clay	2	60
Gray clay	60	120
Blue clay	120	170
Gray Basalt	170	225
Red silt	225	260

RECEIVED

MAR 1 2 2012

WATER RESOURCES DEPT  
SALEM, OREGON

Date Started 9-29-10 Completed 10-29-10

(unbonded) Water Well Constructor Certification  
I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

License Number \_\_\_\_\_ Date \_\_\_\_\_  
Signed \_\_\_\_\_

(bonded) Water Well Constructor Certification  
I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

License Number 1654 Date 10-12-11  
Signed [Signature]  
Contact info (optional)  
Search Drilling INC  
70M Search 501-576-2189

ORIGINAL - WATER RESOURCES DEPARTMENT ONE COPY FOR CONSTRUCTOR ONE COPY FOR CUSTOMER  
SUBMITTED TO THE WATER RESOURCES DEPARTMENT WITHIN 30 DAYS OF COMPLETION OF WORK

01/02/2009

# LAKE 52368

May 15<sup>th</sup>, 2014


Oregon Water Resources Department  
Attn: Buffy Gillis  
725 Summer Street NE, Suite A  
Salem, OR 97301

Dear Ms. Gillis,

Below is a list of the correct locations of the wells therein identified. Well driller Tom Search sent your office the corrected well logs for LAKE 1507 and LAKE 52487. Schroeder Law Offices sent your office the corrected well logs for the remaining wells.

Well #	Well Log #	Township, Range, Section, Quarter-Quarter
Well 1	LAKE 3030	30 South, 17 East, Sec. 8 NE NW
Well 2	LAKE 1507	30 South, 17 East, Sec. 8 NE NW
Well 3	LAKE 4444	30 South, 17 East, Sec. 8 NE NW
Well 4	LAKE 3029	30 South, 17 East, Sec. 8 NE NW
Well 6	LAKE 52368	30 South, 17 East, Sec. 5 SW SE
Well 7	LAKE 52369	30 South, 17 East, Sec. 8 NE NW
Well 8	LAKE 52487	30 South, 17 East, Sec. 5 NW SE

Sincerely,



Thomas MacDonald  
Desert Springs Trout Farm

RECEIVED BY OWRD

MAY 19 2014

SALEM, OR

LAKE 52368



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.oregon.gov/owrd

Application for Well ID Number

DEC 10 2019

Do not complete if the well already has a Well Identification Number.

OWRD

I. OWNER INFORMATION

Current Owner Name (please print): Western Development Group, LP - Attention: Bernie Burkholder
Mailing Address: PO Box 40
City, State, Zip: Summer Lake, OR 97640
Mail Well ID to: [X] SAME AS ABOVE [ ] In Care Of (C/O)
Name & Address:
City, State, Zip:

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 30 S (North / South) Range: 17 E (East / West) Section: 5 SW 1/4 of the SE 1/4
Tax Lot (usually last 3-5 numbers of Tax Map #): 600 County Lake
GPS Coordinates: 42 59' 28.27" N 120 43' 50.53" W
Street Address of Well, City: 48413 Desert Springs Rd Summer Lake
If the property had a different street address in the past:

III. GENERAL WELL INFORMATION (Please fill out as completely as possible, AND attach copy of Well Report, if available)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Fish culture and Irrigation
Date Well Constructed (or property built): 10-28-10 Total Well Depth: 260' Casing Diameter: 12"
Owner at time the well was constructed (if known): Well Report # (if known): Lake 52368
Other Information: Previously assigned Well I.D. Label # L103897 has been lost

SUBMITTED BY (please print): Ethan Negus
PHONE: (541) 943-3192 EMAIL &/or FAX: ethan.negus@desertspringstroutfarm.com

Send application to: Oregon Water Resources Department 725 Summer St NE, Suite A, Salem, Oregon 97301; or fax to (503) 986-0902. Applications are processed in the order they are received, and Well ID Numbers are mailed within 4-5 business days.

\* Replacement tag!

For Official Use Only by the Oregon Water Resources Department:

Received Date:

12-10-19

Well Report Number:

LAKE 52368

Well Identification #:

L-137024