NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

(Please type or pri Do not write above this line)

	10/11/1
State	Well No. 285/14E-15Cd
State	Permit No

(1) OWNER:	(10) LOCATION OF WELL:
Name CAMERON CLIFF	County LAKE Driller's well number
Address DIAMOND BAR RANCH	N 13 14 N 1- 1/4 Section 2,2 T. 2 7 SR. 14 /= W.M.
SILVER LAKE OREGON 97038	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 245 ft.
Rotary Driven Domestic Industrial Municipal Cable	Static level ft. below land surface. Date 3/3/8
Dug □ Bored □ Irrigation X Test Well □ Other □	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded Wel	(12) WELL LOG: Diameter of well below casing Job ft. Depth drilled 300 ft. Depth of completed well 300 ft.
	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	CLOV AND GRAVEL MIXED 65 96
perforations from ft. to ft.	BACALT MARD. 96 136
perforations from ft. to ft.	13FD CINDEIRS - 136 172
	CBEY SHATE . 172 220
(7) SCREENS: Well screen installed? Yes No	HARD BASALT. 110 245
Manufacturer's Name	1 13 17 C/N 10 F/RS 24/5 282 44
Type Model No. Diam. Slot size Set from ft. to ft.	NARD UNKINICIRAL 282 300
Diam. Slot size Set from ft. to ft.	-
(A) YEVER F INTEGRAL Drowdown is amount water level in	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes [] No If yes, by whom? Owkill	KEGEIVEN
Yield: 2.766 gal./min, with 60 ft. drawdown after 2 hrs.	AUC 3 1 1000
n n	AUG 1 1 1980
" " "	WATER RESOURCES DEPT
Bailer test gal./min. with ft. drawdown after hrs.	SALEM, OREGON
Artesian flow g.p.m.	
hperature of water Depth artesian flow encountered ft.	Work started 4 / 25 19 Completed 3 5 19 8
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5/6 19 86
Well seal—Material used (EMFNT CBOOT)	Drilling Machine Operator's Certification:
Well sealed from land surface to ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.
Diameter of well bore below seal	[Signed] Date Date 1980
Number of sacks of cement used in well seal	Drilling Machine Operator's License No. 323
How was cement grout placed?	
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? XYes 🗆 No Plugs Size: location ft.	Name LEONABA CHRISTENSEN
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 130× 23 514VBBH111 0B13 97638
Method of sealing strata off	[Signed] & Christen
Was well gravel packed? Yes No Size of gravel:	(Water Well Contractor)
Gravel placed fromft. toft.	Contractor's License No. / 6 / Date 1980