

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

SALEM, OREGON

State Permit No.

LANE 10032

(1) OWNER:

Name CLC To Zehner

Address Box 198
Springfield Ore

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

5" Diam. from 0 ft. to 50 ft. Gage
" Diam. from 0 ft. to 0 ft. Gage
" Diam. from 0 ft. to 0 ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from 0 ft. to 0 ft.
perforations from 0 ft. to 0 ft.
perforations from 0 ft. to 0 ft.
perforations from 0 ft. to 0 ft.
perforations from 0 ft. to 0 ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 18 ft. below land surface Date 2/25/66
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
20 gal./min. with 10 ft. drawdown after 2 hrs.
" " " " " " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 18 ft.

Diameter of well bore to bottom of seal 8 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number
1/4 1/4 Section 28 T. 17S R. 1W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 5

Depth drilled 50 ft. Depth of completed well 50 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>Loam</u>	<u>0</u>	<u>12</u>	
<u>Sand + gravel</u>	<u>12</u>	<u>24</u>	
<u>sediment gravel</u>	<u>24</u>	<u>38</u>	
<u>Sand + gravel</u>	<u>38</u>	<u>50</u>	
<u>water bearing</u>			<u>18</u>

Work started 2/20 19 66 Completed 2/25 19 66
Date well drilling machine moved off of well 2/25 19 66

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] P. D. Zehner Date 2/25, 19 66
(Drilling Machine Operator)

Drilling Machine Operator's License No. 24

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barnes Bros Well Drilling
(Person, firm or corporation) (Type or print)

Address Box 198 Springfield Ore

[Signed] P. D. Zehner
(Water Well Contractor)

Contractor's License No. 306 Date 2/25, 19 67