NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED NOV 29 1977 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) Do not write above this line.

RECEIVED OCT 20 1977 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 17S/1W-28c

State Permit No. LANE 10063

(1) OWNER:
Name Christian Enterprises
Address P.O. Box 678 Lyd. Ore. 97477

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 88 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom?
Yield: 30 gal./min. with 35 ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 24 sacks
How was cement grout placed? mixed & pumped
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number
SW ¼ NE ¼ Section 28 T. 17S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 15 ft. below land surface. Date 9/28/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 90 ft. Depth of completed well 90 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4'	
Clay & Gravel	4'	14'	
Sand Gravel & Boulders	14'	23'	
Cemented Sand & Gravel	23'	40'	15'
Sand Gravel & Boulders	40'	60'	
Blue Clay	60'	88'	
Sand & Gravel	88'	90'	
Blue Rock		90'	15'

Work started 9/14 1977 Completed 9/22 1977
Date well drilling machine moved off of well 9/28 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Frank Wilson (Drilling Machine Operator) Date 9/30, 1977
Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name W.W. Drilling & Pump Svc. (Person, firm or corporation) (Type or print)
Address 2320 Main St. Lyd. Ore. 974
[Signed] Walt Wilson (Water Well Contractor)
Contractor's License No. 268 Date 10/7, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119