

(1) OWNER:

Name Allen L. LeVay
Address Camp Creek Rd
Pt. 2 Box 400 Springfield
SALEM, OREGON

(2) LOCATION OF WELL:

County Lane Owner's number, if any—
1/4 1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☒
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐

5" Diam. from 0 ft. to 22 ft. Gage 14"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used torch

SIZE of perforations 1/4 in. by 6 in.
24 perforations from 18 ft. to 22 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 9 ft. below land surface Date 5-20-57
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Allen L. LeVay Date May 22, 1957
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well 5 inches.

Depth drilled 22 ft. Depth of completed well 22 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
driven pipe		
topsoil	0	3 1/2
course gravel	3 1/2	10
fine gravel & sand	10	20
course gravel	20	22

Work started 5-20 1957 Completed 5-20 1957

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MARK CHRISTENSEN
(Person, firm, or corporation) (Type or print)

Address 3550 W 18th

Driller's well number 416

[Signed] Mark W. Christensen
(Well Driller)

License No. 97 Date May 20, 1957