NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

LANE 10282

RECEIVED
JAN 31 1974
STATE ENGINEER
SALEM, OREGON

State Well No. 17S/1W-32 6
State Permit No.

(1) OWNER:
Name Wally Quall
Address 2715 Chuchanut
Eugene, Oregon 97401

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6 " Diam. from 0 ft. to 47 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Mills Knife
Size of perforations 2 in. by 1/4 in.
51 perforations from 30 ft. to 46 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 21 gal./min. with 24 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 49 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water 133 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number 601/22
¼ NW ¼ Section 32 T. 17 R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 30 ft.
Static level 6 ft. below land surface. Date 1-15-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 47 ft. Depth of completed well 47 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Sandy Top Soil	0	3	
Sand-Gravel With Large Boulders	3	13	
Hard Cemented Gravel	13	24	
Grey Sand	24	30	
Sand-Gravel	30	43	6
Hard Cemented Gravel	43	47	6

Work started 1-10 1974 Completed 1-16 1974
Date well drilling machine moved off of well 1-18 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Arthur N. Gerin Date 1-25, 1974.
(Drilling Machine Operator)
Drilling Machine Operator's License No. 717

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Carter's Drilling & Pump Service
(Person, firm or corporation) (Type or print)
Address P.O. Box 46 Springfield, Oregon
[Signed] James J. Carter
(Water Well Contractor)
Contractor's License No. 216 Date 1-28, 1974

BCC 1-10-74 (USE ADDITIONAL SHEETS IF NECESSARY) 126 SP*45656-119