

RECEIVED

JAN 9 1985

175/2W-3  
LANE 10388  
(for official use only)

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

WATER RESOURCES DEPT.  
PLEASE TYPE OR PRINT IN INK  
SALEM, OREGON

(1) OWNER:

Name Springfield Country Club  
Address 40545 MARCOJA Rd  
City Springfield State OR

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air  Driven   
Rotary Mud  Dug   
Cable  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Thermal   
Irrigation  Withdrawal  Reinjection   
Other: Commercial  Test   
Piezometric  Grounding

(5) CASING INSTALLED:

Steel  Plastic   
Threaded  Welded   
6" Diam. from 41 ft. to 34 ft. Gauge 2.50, 2.50  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

LINER INSTALLED:

Steel  Plastic   
Threaded  Welded   
6" Diam. from 100 ft. to 20 ft. Gauge 1.60

(6) PERFORATIONS:

Perforated?  Yes  No  
Size of perforations 1/4 in. by 6 in.  
80 perforations from 100 ft. to 80 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Id: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air test 20 gal./min. with drill stem at 100 ft. 1 hrs.  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Special standards: Yes  No   
Well seal—Material used Cement grout  
Well sealed from land surface to 34 ft. 10 ft. 34 ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Diameter of well bore below seal \_\_\_\_\_ in.  
Amount of sealing material \_\_\_\_\_ sacks  pounds   
How was cement grout placed? Neathead  
Was pump installed? no Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL by legal description:

County LANE 1/4 1/4 of Section 3 of  
Township 17 S, Range 24, WM.  
(Township is North or South) (Range is East or West)  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
MAILING ADDRESS OF WELL (or nearest address) same

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 80 ft.  
Static level 15 ft. below land surface. Date 11-21-84  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 8 ft.  
Depth drilled 100 ft. Depth of completed well 98 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil + gravel + clay	0	14	
gravel + clay	14	80	
Broken Rock	80	95	15
Broken Rock (Red)	95	100	

Date work started 11-20-84 / completed 11-21-84  
Date well drilling machine moved off of well 11-21-84

(unbonded) Water Well Constructor Certification (if applicable):  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Carl P. Piche Date 11-23-84, 1984

(bonded) Water Well Constructor Certification:  
Bond 494 issued by: \_\_\_\_\_ (Surety Company Name)  
On behalf of Pitche Pump & Drilling (type or print name of Water Well Constructor)  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
[Signed] Carl P. Piche (Water Well Constructor)  
(Dated) 11-23-84