NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED NOV 29 1977 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED OCT 20 1977 WATER RESOURCES DEPT SALEM, OREGON

State Well No. 17S/2W-24dd
State Permit No. LANE 10637

(1) OWNER:
Name Bob Durbin
Address 37598 Upper Camp Creek Rd. Spfd. Ore. 97477

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 230 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Mills Knife
Size of perforations 1/4 in. by 3 in.
100 perforations from 120 ft. to 195 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
~~Bailer~~ Blow test 27 gal./min. with 110 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 80 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
How was cement grout placed? Trimied & Poured
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number
NE 1/4 SE 1/4 Section 24 T. 17S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 120 ft.
Static level 100 ft. below land surface. Date 8/29/77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 235 ft. Depth of completed well 235 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	6'	
Brown clay	6'	25'	
yellow Sandy clay	25'	60'	
Cemented Sand & Gravel	60'	210'	
Sandy clay	210'	225	100'
Cemented S. Gravel	225	235	100'

Work started 8/23 1977 Completed 8/26 1977
Date well drilling machine moved off of well 8/29 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Frank Wilson (Drilling Machine Operator) Date 8/29, 1977
Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name W.W. Drilling + Pump Ser. (Person, firm or corporation) (Type or print)
Address 2320 Main St. Spfd. Ore. 97477
[Signed] Walt Wilson (Water Well Contractor)
Contractor's License No. 268 Date 8/29, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119