

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**RECEIVED**  
JUN 1 - 1972  
STATE OF OREGON  
WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON  
within 30 days from the date  
of well completion.

STATE ENGINEER  
SALEM, OREGON  
(Do not write above this line)

State Well No. 17/3W-8ca  
State Permit No. LANE 11012

**(1) OWNER:**

Name Harris B. Holtan  
Address 560 11th Ave E  
Eugene, Or 97401

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
8" Diam. from 0 ft. to 63 ft. Gage 1250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
d: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 70 gal./min. with 4 ft. drawdown after 1 hrs.  
Artesian flow g.p.m.  
Temperature of water 51° Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used BENTONITE  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal sacks  
Number of sacks of bentonite used in well seal 3 sacks  
Brand name of bentonite YELLOWSTONE  
Number of pounds of bentonite per 100 gallons of water 133 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Lane Driller's well number 294  
NE 1/4 SW 1/4 Section 8 T.17S R. 3W W.M.  
Bearing and distance from section or subdivision corner

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 40 ft.  
Static level 16 ft. below land surface. Date 5/24/72  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing  
Depth drilled ft. Depth of completed well ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	3	
LARGE GRAVEL	3	12	
GRAVEL + CLAY	12	22	
COARSE SAND + CLAY	22	26	
GRAVEL + COARSE SAND	26	37	
SAND + CLAY	* 37	57	23
GRAVEL	* 57	63	16

Work started 5/22 1972 Completed 5/26 1972  
Date well drilling machine moved off of well 5/26 1972

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] John P. Bridges Date 5/26 1972  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 747

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Miller-Jensen Company (Type or print)  
Address P O Box 2571 Eugene, Or 97402  
[Signed] Harry A. Miller Owner  
(Water Well Contractor)  
Contractor's License No. 179 Date 5-30-72, 19\_\_