

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

MAY 21 1974

State Well No. 175/3W-8

State Permit No. LANE 11023

STATE ENGINEER
SALEM, OREGON

66993

(1) OWNER:

Name Dominique Minaberrigaray
Address 3975 Gilham Road
Eugene, Org 97101

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

8" Diam. from 2 ft. to 82 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " " " "

" " " " " "

Bailer test 60 gal./min. with 7 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.

Temperature of water 52 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE

Well sealed from land surface to 22 ft.

Diameter of well bore to bottom of seal 12 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal _____ sacks

Number of sacks of bentonite used in well seal 3 sacks

Brand name of bentonite YELLOWSTONE

Number of pounds of bentonite per 100 gallons

of water 133 lbs./100 gals.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 387
SE $\frac{1}{4}$ NW $\frac{1}{4}$ Section 8 T. 17S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 50 ft.
Static level 17 ft. below land surface. Date 5/10/74
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 83 ft. Depth of completed well 83 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|----------------------|------|----|-----|
| SOIL | 0 | 4 | |
| SAND & GRAVEL | 4 | 30 | |
| SAND & CLAY | 30 | 58 | |
| COARSE SAND + GRAVEL | 58 | 83 | |

Work started 5/3 1974 Completed 5/10 1974
Date well drilling machine moved off of well 5/10 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Tom P. Rung Date 5/10, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 747

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Miller-Jensen Company
(Person, firm or corporation) (Type or print)
Address P O Box 2571 Eugene, Or 97402

[Signed] Harry A. Miller Owner
(Water Well Contractor)

Contractor's License No. 179 Date May 13, 1974, 1974