

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED

MAY 9 1985

PLEASE TYPE or PRINT IN INK
WATER RESOURCES DEPT
SALEM, OREGON

None
 1145

173/5W-29dc

(for official use only)

(1) OWNER:

Name Robert Kloehn
 Address 25975 Marina dr
 City Veneta State OR

(10) LOCATION OF WELL by legal description:

County Lane SW 1/4 SE 1/4 of Section 29 of
 Township 17S Range 5W WM.
 (Township is North or South) (Range is East or West)
 Tax Lot _____ Lot _____ Block _____ Subdivision _____
 MAILING ADDRESS OF WELL (or nearest address) same

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
 Rotary Mud Dug
 Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Thermal:
 Irrigation Withdrawal Reinjection
 Other:
 Piezometric Grounding Test

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 40 - 45' ft.
 Static level 40 ft. below land surface. Date 5-6-85
 Artesian pressure _____ lbs. per square inch. Date _____

(5) CASING INSTALLED:

Steel Plastic
 Threaded Welded
 " Diam. from 1 1/2 ft. to 1.58 ft. Gauge 2.50
 " Diam. from _____ ft. to _____ ft. Gauge _____

LINER INSTALLED:

Steel Plastic
 Threaded Welded
 " Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS:

Perforated? Yes No
 Size of perforations 1/8 in. by 1/8 in.
440 perforations from 120 ft. to 130 ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Air test 70 gal./min. with drill stem at 130 ft. 2 hrs.
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m.
 Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No
 Well seal—Material used Cement Grout
 Well sealed from land surface to 38 ft.
 Diameter of well bore to bottom of seal 6 in.
 Diameter of well bore below seal 10 in.
 Amount of sealing material 12 sacks pounds
 How was cement grout placed? With over reamer in the ground at a depth of 38; the cement was pumped into over reamer until it came up
 Was pump installed? _____ Type _____ HP _____ Depth _____ ft.
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of Water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(12) WELL LOG:

Diameter of well below casing 6.0
 Depth drilled 220 ft. Depth of completed well 220 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing stratá.

MATERIAL	From	To	SWL
Brown Sandy Clay	0	10	
Brown Clay	10	40	
Sand & Gravel (Small)	40	105	
Clay	105	120	
Sand & Gravel (Small)	120	130	
Sand	130	138	
Blue Sand-y Clay	138	215	
Gray Sand stone	215	220	

→ To The surface on the outside of the overreamer, then the overreamer was extracted and the annular space re-filled with a trimmie pipe

Date work started 4-12-85 /completed 5-6-85
 Date well drilling machine moved off of well 5-6-85 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19 _____

(bonded) Water Well Constructor Certification:

Bond 800174 Issued by Contractors Bonding Co
 (number) (Surety Company Name)
 On behalf of Art Holte
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Art Holte
 (Water Well Constructor)

(Dated) 5-6-85

NOTICE TO WATER WELL CONSTRUCTOR
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
 SALEM, OREGON 97310
 within 30 days from the date of well completion.

SP*46866-690