

RECEIVED

Duplicate

MAY 23 1952

WATER WELL REPORT

17/3W-31 R

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER STATE OF OREGON

G 2225

State Well No.

State Permit No.

LANE 11479

(1) OWNER:

Name Whinn, Shinn & Company
Address 1600 Oak Street
Eugene, Oregon

(2) LOCATION OF WELL:

County Lane Owner's number, if any--
SE 1/4 SE 1/4 Section 31 T. 17 S R. 3 W.M.
Bearing and distance from section or subdivision corner
5' South and 95' West from SW Corner of
Intersection of 16th East and Oak
35' North and 1195' West of SE Corner of Sec 31
S R 3W

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

no joint Threaded [ ] Welded [ ]
8" Diam. from 0 ft. to 17' 3" ft. Gage .188
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [ ] Yes [ ] No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [ ] Yes [ ] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

CONSTRUCTION:

well gravel packed? [ ] Yes [X] No Size of gravel:
well placed from ft. to ft.
a surface seal provided? [X] Yes [ ] No To what depth? 17 ft.
erial used in seal-- Clay
any strata contain unusable water? [ ] Yes [ ] No
e of water? Depth of strata
hod of sealing strata off

(9) WATER LEVELS:

ic level 20 ft. below land surface Date 10/10/59
sian pressure lbs. per square inch Date

Accepted by:

[Signed] Date 19

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 30 gal./min. with 150 ft. drawdown after 8 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 397 ft. Depth of completed well 397 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: Top soil and clay (0-14), Blue gray course marine sandstone (14-367), Brown tuffaceous sandstone (367-397).

Work started 10-3 19 59 Completed 10-10 19 59

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Mark Christensen
(Person, firm, or corporation) (Type or print)

Address 3550 West 18th, Eugene, Oregon

Driller's well number

[Signed] /s/ Mark Christensen
(Well Driller)

License No. 97 Date 09