NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No. 17S/5W-36db

State Permit No.

RECEIVED JUN 19 1978 WATER RESOURCES DEPT. SALEM, OREGON

(1) OWNER:

Name: Dayton C Peck

Address: 825 Walnut St.
Junction City, OR 97748

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded [ ]

6" Diam. from +1 ½ ft. to 39 ½ ft. Gage .250

" Diam. from ft. to ft. Gage

Liner 5" Diam. from 31 ft. to 101 ft. Gage .250

(6) PERFORATIONS: Perforated? [ ] Yes [ ] No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [ ] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 23 gal./min. with 45 ft. drawdown after 1 hrs.

Artesian flow -- g.p.m. --

Temperature of water 53° Depth artesian flow encountered -- ft.

(9) CONSTRUCTION:

Well seal—Material used: Portlant Cement

Well sealed from land surface to 26 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 8 sacks

How was cement grout placed? Pressure grout from bottom of seal to top.

Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.

Did any strata contain unusable water? [ ] Yes [X] No

Type of water? -- depth of strata --

Method of sealing strata off --

Was well gravel packed? [ ] Yes [X] No Size of gravel:

Gravel placed from -- ft. to -- ft.

(10) LOCATION OF WELL:

County: Lane Driller's well number: A101

NW ¼ SE ¼ Section 36 T. 17S R. 5W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 28 ft.

Static level 28 ft. below land surface. Date 5/12/78

Artesian pressure -- lbs. per square inch. Date --

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 101 ft. Depth of completed well 101 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. **Report each change in position of Static Water Level and indicate principal water-bearing strata.**

MATERIAL	From	To	SWL
Top Soil - Brown	0	1	
Clay - Brown	1	21	
Clay - Blue	1	28	28
Sandstone - Blue - Med. Grain	28	29	
Boulder - Erratic - Hard	29	32	
Sandstone - Blue - Med.	32	51	28
Sandstone - Blue - Fine	51	69	
Claystone - Blue - Fine	69	98	28
Clay - Red - Hard	98	101	28

Work started 5/12 1978 Completed 5/30 1978

Date well drilling machine moved off of well 5/30 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James L. Wilson (Drilling Machine Operator) Date 5/30, 1978

Drilling Machine Operator's License No. 1162

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MILLER-JENSEN COMPANY (Person, firm or corporation) (Type or print)

Address P.O. Box 2571, Eugene, Oregon 97402

[Signed] Tracy C. Miller (Water Well Contractor) (Owner)

Contractor's License No. 179 Date May 30, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119