

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy  
 of this report are to be  
 filed with the  
 STATE ENGINEER, SALEM, OREGON 97310  
 within 30 days from the date  
 of well completion.

WATER WELL REPORT

STATE OF OREGON  
 (Please type or print)

RECEIVED  
 JUN 8 1967  
 STATE ENGINEER

State Well No. 17/4w-25  
 State Permit No. LANE 12385

(1) OWNER:

Name IRECO Irrigation  
 Address 1360 BETHEL DR.  
EUGENE - OREGON

(2) LOCATION OF WELL:

County LANE Driller's well number  
 1/4 Section 25 T. 17S R. 4W W.M.  
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 13.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
 10" Diam. from 0 ft. to 140 ft. Gage 250  
 " Diam. from " ft. to " ft. Gage  
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used Mills Knife  
 Size of perforations 1/4 in. by 2 in.  
 500 perforations from 18 ft. to 140 ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.  
 perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name  
 Type Model No.  
 in. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT  
 Depth of seal 18 ft. Was a packer used? SAND  
 Diameter of well bore to bottom of seal 12 in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel:  
 Gravel placed from " ft. to " ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 5/3/67  
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? W.W. Drilling  
 Yield: 380 gal./min. with 70 ft. drawdown after 1 hrs.  
 " 300 " 30 " 2 "  
 " 250 " 20 " 3 "  
 Return test: 380 gal./min. with 70 ft. drawdown after 4 hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 10  
 Depth drilled 140 ft. Depth of completed well 140 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY	0	10
BROWN SAND-GRAY CLAY	10	22
SAND-GRAVEL	22	35
GRAVEL-CLAY (BROWN)	35	60
GRAVEL-CLAY (GRAY)	60	95
Blue CLAY-GRAVEL	95	102
SAND-GRAVEL-CLAY (BROWN)	102	135
SAND-GRAVEL	135	140

Work started 4/17 1967 Completed 5/3 1967  
 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name  
 Type: H.P.  
 Water Well Contractor's Certification:  
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
 NAME W.W. Drilling & Pump Ser.  
 (Person, firm or corporation) (Type or print)  
 Address 2320 MAIN - Springfield  
 Drilling Machine Operator's License No. 24  
 [Signed] Walt Ewilson  
 (Water Well Contractor)  
 Contractor's License No. 268 Date May 5, 1967