

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

DEC - 3 1962

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

State Well No. 17/4W - 33 B(2)

State Permit No. LANE 12606

G2700

**(1) OWNER:**

Name West Lawn Memorial Cemetery  
Address R75, Box 171  
Eugene, Oregon

**(2) LOCATION OF WELL:**

County Lane Driller's well number \_\_\_\_\_  
1/4 Section 33 T. 17S R. 4W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(3) TYPE OF WORK (check):**

Well  Deepening  Reconditioning  Abandon   
 abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(6) CASING INSTALLED:**

Threaded  Welded   
8" Rod Diam. from 0 ft. to 52 ft. Gage .250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:**

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:**

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used in seal Bentonite  
Depth of seal 20 ft. Was a packer used? no  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**

Static level 5 ft. below land surface Date 11-9-62  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 45 gal./min. with 55 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

**(12) WELL LOG:**

Diameter of well below casing 8  
Depth drilled 230 ft. Depth of completed well 230 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay	0	10
Clay + gravel	10	20
Sand + gravel + clay	20	40
only small amounts of water - not good water bearing formation		
Very compact sand + gravel	40	46
practically no water		
Clay	46	52
Rock - sedimentary - mostly claystone or tuffaceous sandstone with occasional harder strips of cleaner sandstone - water bearing at approx 55' + 80' + 90' and increases to 125'	52	230
not possible to accurately determine increases after 125'		
Bottom of well in claystone 230		

Work started 9-24 1962 Completed 10-26 1962  
Date well drilling machine moved off of well 11-9 1962

**(13) PUMP:**

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WAYNE HAYES WELL DRILLING  
(Person, firm or corporation) (Type or print)  
Address 220 Coburg Rd, Eugene, Oregon  
Drilling Machine Operator's License No. 159  
[Signed] Wayne Hayes  
(Water Well Contractor)  
Contractor's License No. 91 Date 11-10, 1962