

RECEIVED
JAN 2 1964

Ochard Point Park
Zumbatt Branch Area Well (LANE) 12775
US Army Eng. 17/5W-3P

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER

STATE OF OREGON

G-2711

State Well No.

State Permit No. G-2531

(1) OWNER:

SALEM, OREGON

Name Honey Miller

Address Walker Oregon

(2) LOCATION OF WELL:

County Lane Owner's number, if any—

1/4 1/4 Section 3 T. 17S R. 5W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

8" Diam. from 0 ft. to 90 ft. Gage 322 ft

" Diam. from _____ ft. to _____ ft. Gage _____

" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills

SIZE of perforations in. by in.

perforations from 50 ft. to 85 ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Was a surface seal provided? Yes No To what depth? 18 ft.

Material used in seal— cement & sand

Did any strata contain unusable water? Yes No

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 12/13/63

Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Mohr's

Yield: 60 gal./min. with 80 ft. drawdown after 8 hrs.

" " " "

" " " "

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow g.p.m. Date _____

Temperature of water 66 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Brown Dirt</u>	<u>0</u>	<u>3</u>
<u>Decomposed Conglomerate</u>	<u>3</u>	<u>15</u>
<u>Conglomerate cemented</u>	<u>15</u>	<u>40</u>
<u>Conglomerate sandy</u>	<u>40</u>	<u>60</u>
<u>Cemented Conglomerate</u>	<u>60</u>	<u>70</u>
<u>Sand & gravel light colored</u>	<u>70</u>	<u>85</u>
<u>Blue silt sand med hard</u>	<u>85</u>	<u>90</u>
<u>Blue siltstone med hard</u>	<u>90</u>	<u>120</u>

Work started 11/25 1963 Completed 12/13/63 1963

(13) PUMP:

Manufacturer's Name _____

Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Mohr's Well Drilling
(Person, firm, or corporation) (Type or print)

Address RT 3 Box 1169 Rose Ore.

Driller's well number 168 Driller's name Stanley G. Mohr

[Signed] Stanley G. Mohr
(Well Driller)

License No. 60 Date 12/13, 1963