

RECEIVED
MAY 8 1962

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 17/SW-21

State Permit No. LANE-13200

(1) OWNER:

Name Ed Childs
Address Rt 2 Box 328
Veneta, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number
1/4 NW 1/4 Section 21 T. 17S R. 5W W.M.
Bearing and distance from section or subdivision corner

(4) below - well to be used for trailer park and camp ground as well as domestic use

(3) TYPE OF WORK (check):

Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

8 5/8" OD Diam. from 0 ft. to 7.6 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite, clay & drilling
Depth of seal 2.9 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 1.0 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 14 ft. below land surface Date 4-7-62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
" " " " "
Bailer test 50 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 76 ft. Depth of completed well 76 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil - Brown	0	1 1/2
Clay - Reddish	1 1/2	19
Clay, sand, gravel - Brown (Compact)	19	29
Sand + gravel - Brown (fairly Compact)	29	46
Sand + gravel - Brown (fairly loose and water bearing)	46	56
Sandy gravel - Blue	56	67
Sand + gravel - Blue - fairly coarse sand and medium gravel - good water bearing formation		
Chemical test showed 2 ppm iron 1/4 of 7.0		
Bottom of hole	76	

Work started 4-2 1962 Completed 4-7 1962
Date well drilling machine moved off of well 4-11 1962

(13) PUMP:

Manufacturer's Name (2) 1 1/2 HP 2 stage Myers
Type: Jet H.P. 1 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DELL PAGE (Person, firm or corporation) (Type or print)

Address Rt 2, Box 449 D, Eugene, Oregon

Drilling Machine Operator's License No.

[Signed] Dell Page (Water Well Contractor)

Contractor's License No. 104 Date 4-7, 1962