

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 17S/5W-26
Lane
State Permit No. 13291

(1) OWNER:

Name Ben Fisher
Address 88460 Fisher Road, Eugene, Or.

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Retary [X] Driven [ ] Domestic [X] Industrial [ ] Municipal [ ]
[ ] Jetted [ ] Irrigation [ ] Test Well [ ] Other [ ]
[ ] Bored [ ]

(5) CASING INSTALLED:

6" Diam. from +1 1/2 ft. to 18 ft. Gage 250
Threaded [ ] Welded [X]
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? [ ] Yes [X] No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Pump test 25 gal./min. with 110 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement grout
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? Pressure grouted.

Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number
1/4 1/4 Section 26 T. 17S R. 5W W.M.
Bearing and distance from section or subdivision corner
Tax Lot #200

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30' ft.
Static level 27' ft. below land surface. Date 5/16/80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Entries include Soil & clay (0-12), Basalt (12-105), Sandstone, blue & grey (105-140) with 27' SWL.

RECEIVED
JUN 3 1980
WATER RESOURCES DEPT
SALEM, OREGON

Work started 5/16 1980 Completed 5/16 19 80
Date well drilling machine moved off of well 5/16 19 80

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl Pitcher Date 5/20, 19 80
(Drilling Machine Operator)

Drilling Machine Operator's License No. 386

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Pitcher Pump & Drilling Company
(Person, firm or corporation) (Type or print)

Address 87829 Greenhill Road, Eugene, Or 97402

[Signed] Carl Pitcher
(Water Well Contractor)

Contractor's License No. 484 Date 5/20, 19 80