

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED SEP 14 1961 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT STATE OF OREGON

LANE 13295 17/5W-28E State Well No.

G1960 State Permit No. G-1801

(1) OWNER: SALEM, OREGON Name Corps of Engineers Address 628 Pittock Block Portland 5, Oregon

(2) LOCATION OF WELL: County Lane Owner's number, if any-- SW 1/4 NW 1/4 Section 28 T. 17 S R. 5 W W.M. Bearing and distance from section or subdivision corner 1635 feet S. and 510 feet E. from NW corner Sec. 28, T. 17 S., R. 5 W.W.M.

(3) TYPE OF WORK (check): New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check): Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [x] (5) TYPE OF WELL: Rotary [ ] Cable [x] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [x] 8" Diam. from 0 ft. to 75 ft. Gage 322wall

(7) PERFORATIONS: Perforated? [ ] Yes [x] No Type of perforator used SIZE of perforations in. by in. perforations from ft. to ft.

(8) SCREENS: Well screen installed [ ] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [x] Yes [ ] No To what depth? ft. Material used in seal- Cement Did any strata contain unusable water? [ ] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 10 ft. below land surface Date 7/28/61 Artesian pressure lbs. per square inch Date Log Accepted by: MERLE E. LIETZKE Chief, Real Estate Division Date 13 September, 1961

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? W. W. Drilling Yield: 68 gal./min. with 50ft. drawdown after 1/2 hrs. 70 " 50 " 1 " 70 " 50 " 4 "

(12) WELL LOG: Diameter of well 8 inches. Depth drilled 75 ft. Depth of completed well 75 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows: Soil (0-2), Yellow clay (2-19), Grey clay (19-28), Fine silt & clay (28-49), Cemented gravel (49-56), Coarse sand (water) (56-75)

Work started 7/18/61 19 Completed 7/28/61 19

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. W. Drilling & Pump Service (Person, firm, or corporation) (Type or print) Address 285 So. 32nd St. Springfield, Oregon Driller's well number 7461 [Signed] Walt Wilson (Well Driller) License No. 268 Date 8/5/61 19