

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

STATE ENGINEER SALEM OREGON

RECEIVED
 DEC 27 1968
 State Well No. 17/5w-31
 State Permit No. LANE
 13450

(1) OWNER:

Name CITY OF VENETA
 Address VENETA, ORETON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

12" Diam. from 0 ft. to 76 ft. Gage .250
 10" Diam. from 72 ft. to 79 ft. Gage .250
 10" Diam. from 119 ft. to 124 ft. Gage .250

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations	in.	by	in.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.
perforations from		ft. to	ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name JOHNSON
 Type STAINLESS STEEL PIPE SIZE 304
 Model No. 79
 Diam. 10" Slot size 50 Set from 96 ft. to 119 ft.
 Diam. 10" Slot size 100 Set from 96 ft. to 119 ft.

(8) WATER LEVEL: Completed well.

Static level 51 ft. below land surface Date 8-3-67
 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? CARTER'S
 Yield: 190 gal./min. with 58 ft. drawdown after 24 hrs.
 " " " "
 " " " "
 Baller test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT
 Depth of seal 32' ft.
 Diameter of well bore to bottom of seal 18 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County LANE Driller's well number
 1/4 Section 31 T. 17S R. 5W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing ---

Depth drilled 124 ft. Depth of completed well 124 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	4	
YELLOW CLAY	4	46	12
SAND- COARSE GRAVEL	46	57	
FINE SAND	57	64	54
COARSE SAND	64	79	
COARSE SAND- GRAVEL	79	124	51

Work started 7-15-67 19 Completed 8-3-67 19

Date well drilling machine moved off of well 8-3-67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Clifford Cronin Date 8-11-67, 19
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 148

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CARTER'S DRILLING & PUMP SERVICE
 (Person, firm or corporation) (Type or print)

Address 325 So. 2nd St., Springfield, Oregon

[Signed] James G. Carter (Water Well Contractor)

Contractor's License No. 126 Date 8-11-67, 19