

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

DEC 3 1964

STATE OF OREGON
(Please type or print)

State Well No. 17/6w-25A

State Permit No. LANE 14839

(1) OWNER:

Name J. D. Smith
Address Elmira, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number 30
NE 1/4 NE 1/4 Section 25 T. 17S R. 6W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 54 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 25 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 10-6-64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 40 gal./min. with 10 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 54 ft. Depth of completed well 54 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Clay</u>	<u>0</u>	<u>18</u>
<u>Sand/Clay</u>	<u>18</u>	<u>35</u>
<u>Sand Gravel</u>	<u>35</u>	<u>54</u>

Work started 10-2 1964 Completed 10-6-64 19
Date well drilling machine moved off of well 11-6-64 19

(13) PUMP:

Manufacturer's Name Jacuzzi
Type: Submersible H.P. 1 1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller-Jensen Company
(Person, firm or corporation) (Type or print)

Address 2880 Elmira Road, Eugene

Drilling Machine Operator's License No. 307

[Signed] Harry A. Miller
(Water Well Contractor) Owner

Contractor's License No. 179 Date 11-5-64, 19__