

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

DEC 30 1974

State Well No.

175/6W-29

STATE ENGINEER

SALEM, OREGON

State Permit No.

LANE 14343

(1) OWNER:

Name Robert J J Wright
Address 88838 Hale Rd
Nati, Oregon 97461

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 7 1/2 ft. to 38 1/2 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____

Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 5 gal./min. with 30 ft. drawdown after 4 hrs.

" " " " " "
AIR
Batter test 7 gal./min. with MAX ft. drawdown after 2 hrs. 12/13/74

Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Grout-bentonite
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 9 5/8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal _____ sacks
Number of sacks of bentonite used in well seal one sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water 40 lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County LANE Driller's well number _____
1/4 Section 29 T. 175 R. 6W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 78 ft.
Static level 26 ft. below land surface. Date 12/13/74
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
BROWN CLAY	2	27	
Blue CLAY	27	32	
TYPE SS	32	100	

1/2 HP 4AL16 BERKELEY
PUMP INSTALLED ON
12-20-74 PUMP WAS
OPERATED AT 5 GPM
& 100# PRESSURE FOR
4 HOURS

Work started 12/10 1974 Completed 12/13 1974
Date well drilling machine moved off of well 12/13 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Frank Christensen, Date 12/16, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 612

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MART CHRISTENSEN
(Person, firm or corporation) (Type or print)

Address Rt 2 Box 438 Eugene 97401

[Signed] Mart Christensen
(Water Well Contractor)

Contractor's License No. 97 Date 12/17, 1974