

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

67368
Well #2

WATER WELL REPORT

RECEIVED

STATE OF OREGON
(Please type or print)

JUN 16 1975

State Well No. 175/6W-29dc

STATE ENGINEER
SALEM, OREGON

State Permit No. LANE 14384

(1) OWNER:

Name Swanson Bros Lumber Co.
Address Noti, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6 3/8" O.D. Diam. from 0 ft. to 37 1/2 ft. Gage 1.250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 40 gal./min. with 25 ft. drawdown after 1 1/4 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 37 1/2 ft.
Diameter of well bore to bottom of seal 10" to 32' 8" to 37 1/2
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 1/2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number
SE 1/4 SW 1/4 Section 29 T. 17S R. 6W W.M.
Bearing and distance from section or subdivision corner
SW corner of Cooling shed

(11) WATER LEVEL: Completed well.

Depth at which water was first found 20-25 ft.
Static level 37 ft. below land surface. Date 5-26-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 110 3/4 ft. Depth of completed well 110 3/4 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay - brown	0	14	
Rock - weathered - brown Soft with some fairly hard spots	14	32	
Rock - Sedimentary - gray - water bearing at approx 65' and 100'	32	110 3/4	37
Bottom of well in gray sedimentary rock	110 3/4		

Work started 5-21 1975 Completed 5-26 1975
Date well drilling machine moved off of well 5-26 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dee Page Date 5-26, 1975
(Drilling Machine Operator)

Drilling Machine Operator's License No.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Hayes & Page Well Drilling, Oregon Ltd.
(Person, firm or corporation) (Type or print)

Address 25861 Hwy 126, Veneta, Oregon 97487

[Signed] Dee Page
(Water Well Contractor)

Contractor's License No. 104 Date 5-26, 1975