

RECEIVED

JUL 27 1984

1456 Lane

189/4W-19

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

PLEASE TYPE OR PRINT IN INK DEPT SALEM, OREGON

(for official use only)

(1) OWNER:

Name C. A. Bowers Address 31479 Camas Lane City Eugene, State Or.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary Air [X] Driven [] Rotary Mud [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Thermal: Withdrawal [] ReInjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

Steel Threaded [X] Plastic Welded [] 6" Diam. from +1 ft. to 19 ft. Gauge 250

LINER INSTALLED:

Steel Threaded [] Plastic Welded []

(6) PERFORATIONS:

Perforated? [] Yes [X] No Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? gal./min. with ft. drawdown after hrs. Air test 2 gal./min. with drill stem at 295 ft. 1 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [X] Well seal—Material used Portland Cement Well sealed from land surface to 19 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Amount of sealing material 5 sacks [X] pounds [] How was cement grout placed? poured thru tremie

Was pump installed? [] Type HP Depth ft. Was a drive shoe used? [] Yes [X] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No not tested Type of Water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:

County Lane 1/4 of Section 19 of Township 18S, Range 4W, WM. Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) SAME AS OWNER

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 210 ft. Static level 270 ft. below land surface. Date 7-25-84 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 295 ft. Depth of completed well 295 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Topsoil, Brown Clay, Red Brown Gray Green Cong., Brown Gray Cong., Gray Green Cong., Brown Claystone, Gray Green Cong., Brown Gray Cong., Gray Green Cong., Brown Cong., Gray Green Cong., Brown Cong., Gray Green Basalt, Gray Green Cong.

Date work started 7-25-84 /completed 7-25-84 Date well drilling machine moved off of well 7-25 19 84

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Bob Murphy Date 7-25, 19 84

(bonded) Water Well Constructor Certification:

Bond 05U452863 Issued by: United Pacific Ins. (number) (Surety Company Name) On behalf of Casey Jones Well Drilling Co., Inc. (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Casey Jones (Water Well Constructor) (Dated) 7-25-84

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690