

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97301 within 30 days from the date of well completion.

RECEIVED

DEC 24 1965

STATE ENGINEER OF OREGON
(Please type or print)
SALEM OREGON

State Well No.

17/1-16

State Permit No.

LANE 14812

(1) OWNER:

Name Lori's Fountain #1
Address 12500 McKenzie Hwy Spfld.

(2) LOCATION OF WELL:

County Lane Driller's well number 32-65
1/4 1/4 Section 16 T. 17 R. 1E W.M.
Bearing and distance from section or subdivision corner

Abandoned well
at 40 ft.

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐
Irrigation ☐ Test Well ☐ Other ☐ Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 64 ft. to 40 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____ Model No. _____
Diam. Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Clay & Catlings
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 12/14/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 15 gal./min. with 10 ft. drawdown after 1/2 hrs.

Bailer test gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow g.p.m. Date _____

Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 40 ft. Depth of completed well Not Completed

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Loam</u>	<u>0</u>	<u>9</u>
<u>Loam & Boulders</u>	<u>9</u>	<u>24</u>
<u>Sand gravel & Boulders</u>	<u>24</u>	<u>35</u>
<u>gravel & Boulders</u>	<u>35</u>	<u>4</u>
<u>Clay</u>		

Bent Casing
at 40' could not
Continue customer
wanted more water
could not go any deeper
so filled in well and
abandoned
Work started 12/6 19 65 Completed Not completed
Date well drilling machine moved off of well 12/14 19 65

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Bonnie Bruewell drilling
(Person, firm or corporation) (Type or print)

Address R#2 Box 198 Spfld Oregon

Drilling Machine Operator's License No. 24

[Signed] P D Zehr
(Water Well Contractor)

Contractor's License No. 307 Date 12/14/65, 19 65