RECEIVED
MAR 10 1966
STATE ENGINEER
SALEM OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 17/1-18
State Permit No. LANE 14873

(1) OWNER:
Name Lester Ramsey
Address 15032 McKenzie Hwy
Springfield Oregon

(2) LOCATION OF WELL:
County Lane Driller's well number 2-66
¼ ¼ Section 18 T. 17S R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from -1 ft. to 29 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cutlings & Clay
Depth of seal 18 ft. Was a packer used? Sand
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 8 ft. below land surface Date 2/10/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 20 gal./min. with 20 ft. drawdown after 1½ hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 32 ft. Depth of completed well 32 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Loam	0	7
clay & Bowlders	7	18
Sand & gravel & clay	18	24
Cement gravel	24	30
Sand & Rock gravel	30	31

Work started 2/7 1966 Completed 2/10 1966
Date well drilling machine moved off of well 2/10 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Bonnie Brae Well Drilling (Person, firm or corporation) (Type or print)
Address R#2 Box 198 Springfield Ore
Drilling Machine Operator's License No. 24
[Signed] [illegible] (Water Well Contractor)
Contractor's License No. 307 Date 2/10, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)