

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED STATE OF OREGON AUG 7 1968 STATE ENGINEER SALEM OREGON

State Well No. 17/1-19 State Permit No. LANE 14884

(1) OWNER:

Name ED WERNER Address 13848 DEERHORN RD SPRINGFIELD, ORE

(2) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

CASING INSTALLED:

6" Diam. from 0 ft. to 64 ft. Gage 250

PERFORATIONS:

Perforated? [] Yes [x] No

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 245 ft. below land surface Date 6/24/68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

(10) CONSTRUCTION:

Well seal—Material used Cement Depth of seal 18 ft. Diameter of well bore to bottom of seal 10 in.

(11) LOCATION OF WELL:

County Lane Driller's well number 1/4 1/4 Section 19 T. 175 R. 1 E W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 330 ft. Depth of completed well 330 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated.

Table with columns: MATERIAL, From, To, SWL. Rows include: Top Soil Balders 0-14', yellow clay Balders 14'-64', Brown Shale 64'-81', Black Basalt 81'-100', Brown Rock 100'-115', Grey rock 115'-130', Black Basalt 130'-145', Blue rock 145'-205', Grey rock 205'-240', Brown Shale 240'-255', Blue rock 255'-280', Black Basalt 280'-310', Grey rock 310'-330' 245'

Work started 6/17 1968 Completed 6/24/68 Date well drilling machine moved off of well 6/24/68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Frank Watson Date 6/26, 1968 (Drilling Machine Operator)

Drilling Machine Operator's License No. 404

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.W. Drilling & Pump Sep. (Person, firm or corporation) (Type or print)

Address 2320 MAIN - Springfield ORE

[Signed] Walt Wilson (Water Well Contractor)

Contractor's License No. 268 Date 6/27, 1968