RECEIVED

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

MAR 1 7 1986

PLEASE TYPE or PRINT IN INK

神神神病 RESOURCES DE	(for official use only)
(1) OWNER:	(10) LOCATION OF WELL by legal description:
Name Rosboro Lumber Co. (RW)	County Lane 14 NW 14 of Section 11 of
Address 2509 Main St.	Township 17S, Range 3E (Range is East or West), WM.
City Springfield State Or	(Township is North or South) (Range is East or West) Tax Lot 0 0 3 0 10t Block Subdivision
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address)
<u> </u>	Finn Rock, Or.
New Well X Deepening Abandon Abandon If abandonment, describe material and procedure in Item 12.	
	(11) WATER LEVEL of COMPLETED WELL:
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 145 ft.
Rotary Air XX Driven	Static level 10 ft. below land surface. Date 2/19/8
Rotary Mud Dug Irrigation Withdrawal Reinjection Other:	Artesian pressure lbs. per square inch. Date
Bored Piezometric Grounding Test	6"
(5) CASING INSTALLED: Steel Plastic Plastic	(12) WELL LOG: Diameter of well below casing
Threaded Welded X	Formation: Describe color, texture, grain size and structure of materials; and show thickness
6" Diam. from	and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED: Steel Plastic Threaded Welded	MATERIAL From To SWL
	Top Soil 0 6
	Sand-Gravel 6 19
(6) PERFORATIONS: Perforated? Yes No	Blue Basalt 19 157 10
Size of perforations in. by in.	
ft. to ft.	
perforations from ft. to ft.	
perforations from ft. to ft.	-
(7) SCREENS: Well screen installed? Yes KNo	
Manufacturer's Name	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes X No If yes, by whom?	
d: gal./min. with ft. drawdown after hrs.	
" " "	-
Air test 15 gal./min. with drill stem at 150 ft. $1\frac{1}{2}$ hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
nperature of water 51° Depth artesian flow encountered ft.	Date work started 2/10/86 /completed 2/19/86
(9) CONSTRUCTION: Special standards: Yes □ No XX	Date well drilling machine moved off of well 2/19/ 1986
Well seal—Material used	(unbonded) Water Well Constructor Certification (if applicable):
Well sealed from land surface to ft.	This well was constructed under my direct supervision. Materials used and
Diameter of well bore to bottom of seal in.	information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Herrant Jan 18th 2/19/, 19 86
Amount of sealing material	[Digitett]
How was cement grout placed?	(bonded) Water Well Constructor Certification: Bond TA57412077 Issued by: Transamerican
	(Surety Company Name)
Was pump installed? n.o Type HP Depth ft.	On behalf of Carter's Drilling & Pump Serv (type or print name of Water Well Constructor)
Was a drive shoe used? Yes XXNo Plugs Size: location ft.	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Did any strata contain unusable water? 🔲 Yes 🖎 No	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
Type of Water? depth of strata	Town of the first
Method of sealing strata off	(Signed) (Water Well Constructor)
Was well gravel packed? Yes No Size of gravel:	(Dated) 3/13/86 (Water Weil Constitution)
Gravel placed from ft. to ft.	
NOTICE TO WATER WELL CONSTRUCTOR	WATER RESOURCES DEPARTMENT, SP*46866-690