NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 185/2W-19 bd
State Permit 66 ANE. 5456

(1) OWNER:	(10) LOCATION OF WELL:
Name Staffordshire	County Lane Driller's well number
Address P.O. Box 668	SE 14 NW 14 Section 19 T. 18 S R. 2 W W.M.
Albany , OR 97321	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 18
Rotary Driven Domestic Industrial Municipal	Static level 8 ft. below land surface. Date 1/-4-79
☐ Bored ☐ Irrigation ☐ Test Well ☐ Other ☐	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded □ Welded □ 250 10 "Diam. from 0 t 2 ft. to 163 ft. Gage 250 "Diam. from ft. to ft. Gage Threaded □ Welded □ 250 "Diam. from ft. to ft. Gage Threaded □ Welded □ 250 "Diam. from ft. to ft. Gage Threaded □ Welded □ 250 "Diam. from ft. to ft. Gage Threaded □ Welded □ 250	(12) WELL LOG: Diameter of well below casing Depth drilled 163 ft. Depth of completed well 163 ft. Formation: Describe color, texture, grain size and structure of materials;
(6) PERFORATIONS: Perforated? No.	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Machine	MATERIAL From To SWL
Size of perforations 3 in. by 3/6 in.	TOPSO11 0 4
2300 perforations from L8 ft. to 148 ft.	Clay 4 13
perforations fromft. toft.	Clay with gravel 13 18
perforations from ft. to ft.	9 Have 1 18 25
(7) SCREENS: Well screen installed? Yes No	clay with gravel 25 36
Manufacturer's Name	gravel 36 50
Type Model No.	Clay 4 gravel 50 147
Diam. Slot size Set from ft. to ft.	blue rock 155
Diam. Slot size Set from ft. to ft.	0142 rock 155 163 7°
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ☐ No If yes, by whom?	
d: gal./min. with ft, drawdown after hrs.	
" " " " " " " " " " " " " " " " " " " "	MAR 2 : 1980 #
# # # # # # # # # # # # # # # # # # #	WATER RESOURCES REDT
Bailer test 60 gal./min. with 20ft. drawdown after 2 hrs.	SALEM, OKEGON
esian flow g.p.m.	
Temperature of water Depth artesian flow encounteredft.	Work started 10-30 1976 Completed 12-13 1979
(9) CONSTRUCTION:	Date well drilling machine moved off of well /2-/3 1979
Well seal-Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface to 60 ft	This well was constructed under my direct supervision
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	19-17 79
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)
How was cement grout placed? Pumped through	Drilling Machine Operator's License No. 1096
A STATE OF THE STA	Water Well Contractor's Certification:
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Did any strata contain unusable water? Ves No	Name W.W. DRILLING-PUMP SALES & SERV., INC
Type of water? Contamine depth of strata 50	Address 2320 Main St. Spfd. OR 97477
Method of sealing strata off Cemen + Seal to 60'	4 1 , 9
Was well gravel packed? ☑ Yes ☐ No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed from 60 m ft. to 163 ft.	Contractor's License No. 562 Date January 4 , 1980
/TION A TANKENON A	17