

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

JUL 16 1973

STATE ENGINEER

SALEM, OREGON

State Well No. 185/5W-216

State Permit No.

(1) OWNER:

Name Frank Jarvis
Address RT 5 Box 1053
Eugene Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6 1/2" ID Diam. from 0 ft. to 34 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 3 1/2 gal./min. with 180 ft. drawdown after 1 hrs.

Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 34 ft.
Diameter of well bore to bottom of seal 10" to 27' 8" to 33 1/2'
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 15 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number
NW 1/4 SE 1/4 Section 21 T. 18 S. R. 5 W. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 20-22 ft.
Static level 6 ft. below land surface. Date 6-16-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 189 1/2 ft. Depth of completed well 189 1/2 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	2 1/2	
Clay - brown	2	15	
Clay - sandy - gray	15	22	8
water in lower part			
just above rock			
Rock - sedimentary -	22	189 1/2	6
gray - water found			
at approx 60' (13 gpm)			
and 155' (2 gpm)			
Some salt content.			
Bottom of well in gray	189 1/2		
sedimentary rock			

Work started 6-11 1973 Completed 6-16 1973
Date well drilling machine moved off of well 6-16 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Deell Page Date 6-16, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 159

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Haves & Page Well Drilling
(Person, firm or corporation) (Type or print)

Address RT 3 Box 218 Veneta, Oregon

[Signed] Deell Page
(Water Well Contractor)

Contractor's License No. 104 Date 6-16, 1973