NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
AUG 18 1975
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 18s/2w-28

State Permit No. LANE 15770

(1) OWNER:

Name Melvin Shores (R.W.)

Address Ridgeway Rd.
Pleasant Hill, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

6 " Diam. from 0 ft. to 120 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used

Size of perforations 1/4 x 3 in. by in.

275 perforations from 65 ft. to 120 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 39 gal./min. with 25 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Bentonite

Well sealed from land surface to 0 to 20 ft.

Diameter of well bore to bottom of seal in.

Diameter of well bore below seal in.

Number of sacks of cement used in well seal 3 sacks

Number of sacks of bentonite used in well seal 2 sacks

Brand name of bentonite Western

Number of pounds of bentonite per 100 gallons of water 133 lbs./100 gals.

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number

¼ S.W.¼ Section 28 T. 18 R. 2-W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 35 ft.

Static level 22 ft. below land surface. Date 7-27-75

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 127 ft. Depth of completed well 127 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown top soil	0	4	
Brown clay	4	20	
Yellow sandy clay	20	40	
Clay with sand-gravel	40	60	
Fine sand and gravel	60	100	
Sand and gravel cemented	100	120	
Cemented sand and gravel	120	127	

Work started 7-25 1975 Completed 7-31 1975

Date well drilling machine moved off of well 8-1 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] (Drilling Machine Operator) Date 8-5, 1975

Drilling Machine Operator's License No. 148

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Carter's Drilling & Pump Service (Person, firm or corporation) (Type or print)

Address P. O. Box 46 Springfield, Oregon 97477

[Signed] (Water Well Contractor)

Contractor's License No. 126 Date 8-5, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119