

RECEIVED
 JUL 11 1966

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

SALEM, OREGON STATE OF OREGON
 (Please type or print)

State Well No. 18/2w-34
 State Permit No. LANE 15969

(1) OWNER:

Name Pleasant Hill School District #1
 Address Rt. #2
Creswell, Oregon

(2) LOCATION OF WELL:

County Lane Driller's well number _____
1/4 Section 34 T. 18S R. 2W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 110 ft. to 134 ft. Gage # 250
 _____ " Diam. from _____ ft. to _____ ft. Gage _____
 _____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated Yes No
 Type of perforator used Mills
 Size of perforations 3/8 in. by 4 in.
60 perforations from 85 ft. to 115 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddle Clay & Cement
 Depth of seal 20 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 6/28/66
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " "
 " " " " "
 Bailer test 100 gal./min. with 40 ft. drawdown after 1 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8 _____
 Depth drilled 25 ft. Depth of completed well 135 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Sand & Gravel</u>	<u>110</u>	<u>135</u>

Work started 6/25/66 19 Completed 6/28/66 19
 Date well drilling machine moved off of well _____ 19

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling
(Person, firm or corporation) (Type or print)
 Address Rt. 2 Box 695 Creswell, Oregon

Drilling Machine Operator's License No. 423

[Signed] Robert Jones
(Water Well Contractor)

Contractor's License No. 103 Date 6-28¹, 19 66