

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

JUN 23 1965 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON (Please type or print) SALEM OREGON

State Well No. 18/3w-1 State Permit No. LANE 16099

(1) OWNER:

Name Pacific Power & Light Co. (M.O.E 2) Address 550 Main Street Springfield, Oregon 97477

(2) LOCATION OF WELL:

County Lane Driller's well number 1 T. 3W R. 18 W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [x] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 55 ft. Gage 3/8" Threaded [] Welded [x]

(7) PERFORATIONS:

Type of perforator used Torch Perforated? [x] Yes [] No Size of perforations 4 in. by 1/2 in. Torch perforations from 22 ft. to 47 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 21 ft. Was a packer used? Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 7'6" ft. below land surface Date 4/23/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Carter's Yield: 1700 gal./min. with 9'6" ft. drawdown after 30 hrs.

(12) WELL LOG:

Diameter of well below casing 16" Depth drilled 55 ft. Depth of completed well 55 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top Soil, Gravel, Sand & Small Cobbles, Coarse Gravel - Heavy Clay, Sand, Gravel & Slight Clay, Clean Sand & Gravel, Sand-Gravel-Clay.

Work started 4/12 19 65 Completed 4/23/ 1965 Date well drilling machine moved off of well 4/23/ 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Carter's Drilling & Pump Service (Person, firm or corporation) (Type or print) Address 325 South 2nd St. Springfield, Oregon

Drilling Machine Operator's License No. 148 [Signed] James J. Carter (Water Well Contractor) Contractor's License No. 126 Date 5/4/ 19 65