

RECEIVED

JUN 23 1965

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 10/3w-1

State Permit No. LANE 16/01

(1) OWNER:

Name Pacific Power & Light Co (M.O.E.) 3
Address 550 Main Street
Springfield, Oregon 97477

(2) LOCATION OF WELL:

County Lane Driller's well number
1/4 Section 1 T. 3W R. 18 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X]
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]
16" Diam. from 0 ft. to 56 ft. Gage 3/8"

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Torch
Size of perforations 1/2 in. by 1/2 in.
Torch perforations from 22 ft. to 47 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 21 ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? [] Yes [] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 11'6" ft. below land surface Date 6/4/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Carter's
Yield: 1000 gal./min. with 9'6" ft. drawdown after 30 hrs.

(12) WELL LOG:

Diameter of well below casing 16
Depth drilled 56 ft. Depth of completed well 56 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top Soil, Sand - Gravel - Heavy Clay, Coarse Gravel - Large Cobbles, 6" to 8" Dia. Heavy Clay, Gravel, Small Cobbles - Clay, Mixed, Sand - Gravel - Slight Clay, Sand - Gravel - Clay Mixed.

Work started 5/17/ 1965 . Completed 6/14/ 1965
Date well drilling machine moved off of well 6/14/ 1965

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Carter's Drilling & Pump Service
(Person, firm or corporation) (Type or print)

Address 325 South 2nd St. Springfield, Oregon

Drilling Machine Operator's License No. 148

[Signed] James J. [Signature]
(Water Well Contractor)

Contractor's License No. 126 Date 6/22/ 1965