

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

JUN 5 1964

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON STATE ENGINEER (Please type or print) SALEM, OREG.

State Well No. 18/3W-13

State Permit No. LANE 16258

(1) OWNER:

Name Harry Wright Address 130 N. 5th, Springfield, Ore.

(2) LOCATION OF WELL:

County Lane Driller's well number 1/4 Section 13 T.18 S R. 3 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X] 6" Diam. from 0 ft. to 99 3/4 ft. Gage .250

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No

Type of perforator used Mills Perforator Size of perforations 3/8 in. by 4 in. perforations from 94 ft. to 63 ft. perforations from 50 ft. to 30 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay & cement Depth of seal 25' & 99 3/4 ft. Was a packer used? Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [ ] Yes [X] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 14.7 10 ft. below land surface Date 3-19-64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [ ] No If yes, by whom? Ramsey -Waite Co

Yield: 105 gal./min. with ft. drawdown after hrs.

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [X] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil, Small & medium gravel, Hard pan, Small & medium gravel, Blue clay stone, soft, Sand & gravel & fine gravel.

Work started 3-9-64 19 Completed 3-19-64 19 Date well drilling machine moved off of well 3--19-64 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Co. (Person, firm or corporation) (Type or print)

Address Rt. 2 Box 695 Creswell, Ore.

Drilling Machine Operator's License No. 186

[Signed] Delbert Jones (Water Well Contractor)

Contractor's License No. 103 Date 3-31-64 19