NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

1633 LANE

RECEIVED
DEC 26 1980
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 19S/1W-8bc
State Permit No.

(1) OWNER:
Name Gus Robertson
Address 38296 Wheeler Road
Dexter, Oregon 97431

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
C[illegible] [X] Jetted [ ]
D[illegible] [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded [X]
6 5/8" Diam. from +1'6" ft. to 28'6 3/4" Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? [X] Yes [ ] No.
Type of perforator used Saw
Size of perforations .040 in. by 3 in.
4½" PVC perforations from Schedule 40 ft. to ft.
perforations from Surface ft. to 60 ft.
360 perforations from 50 ft. to 60 ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
[illegible]s a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
[illegible]ailer test 40 gal./min. with 24 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement
Well sealed from land surface to 27 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? Pumped
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Lane Driller's well number 605-164
SW ¼ NW ¼ Section 8 T. 19 S R. 1 W W.M.
Bearing and distance from section or subdivision corner
Near SW Corner of DLC No. 51

(11) WATER LEVEL: Completed well.
Depth at which water was first found 6 ft.
Static level 5'10" [X] below land surface. Date 11/28/80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	5	
Rock, Brown, fractured	5	9	4'6"
Rock, Blue, fractured	9	13	5'10"
Rock, blue	13	18	"
Rock, blue, some frac.	18	20	"
Rock, blue	20	39	"
Rock blue, some frac.	39	45	"
Rock, blue	45	60	"

Work started 11/21/ 1980 Completed 11/28/ 1980
Date well drilling machine moved off of well 11/28/ 1980

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John L Hoeck (Drilling Machine Operator) Date 12/15, 1980
Drilling Machine Operator's License No. 931

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Hoeck Well Drilling (Person, firm or corporation) (Type or print)
Address P. O. Box 1577, Eugene, OR 97440
[Signed] John L Hoeck (Water Well Contractor)
Contractor's License No. 605 Date Dec. 15, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119