RECEIVED

STATE OF OREGON

JUN 1 3 1985

WATER WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPRO PRINT IN INK

185/3W-28 LANE 16555

(1) OWNER:	(10) LOCATION OF WELL by lega	l description:
Name Butterfield Development Co.	<u> </u>	of Section 28 of
Address 1063 High St. Suite 1A	Township 188 , Range	3W , wm.
City Eugene State Or	(Township is North or South)	Range is East or West)
(2) TYPE OF WORK (check):	Tax Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) 1 mi	
New Well 【 Deepening □ Reconditioning □ Abandon □ If abandonment, describe material and procedure in Item 12.	Eagle Ares Rd. off Dillard Rd	. Eugene
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLET	ED WELL:
Rotary Air XX Driven Domestic Industrial Municipal	Depth at which water was first found	45 ft.
Thermal:		land surface. Date 5-22-85
Other:		square inch. Date
Bored Diezometric Grounding Test	(12) WELL LOG: Diameter of well below	. 6"
(5) CASING INSTALLED: Steel Threaded Welded 6 Diam. from +1 ft. to 19 ft. Gauge 250	Depth drilled 185 ft. Depth of Formation: Describe color, texture, grain size and structure and nature of each stratum and aquifer penetrated, with at 1	completed well 185 ft. of materials; and show thickness east one entry for each change of
"Diam. fromft. to	formation. Report each change in position of Static Wat water-bearing strata.	er Level and indicate principal
LINER INSTALLED: Steel		
	MATERIAL	From To SWL
"Diam. from	Topsoil	0 1
(6) PERFORATIONS: Perforated? 🗆 Yes 💆 No	Gray Clay Gray Brown Sandy Clay	3 6
Size of perforations in. by in.	Gray Brown Sandstone	6 9
perforations from ft. to ft.	Blue Sandstone	9 91
perforations from ft. to ft.	Gray Blue Green Brown Cong.	91 112
perforations from ft. to ft.	Gray Blue Brown Sandspone	112 119
(7) SCREENS: Well screen installed? Yes No	Grav Sandstone	119 170
Manufacturer's Name	Gray Green Sandy Claystone	170 173
TypeModel No	Hard Gray Green Sandstone	173 185
Diam Slot Size		
Diam Slot Size Set from ft. to ft.		,
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
		=
Was a pump test made? Yes X No If yes, by whom? gal./min. with ft. drawdown after hrs.		
d: gal./min. with ft. drawdown after hrs.		
Air test 30 gal./min. with drill stem at 185 ft. 1 hrs.	* .	
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.		
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\subseteq \)	Date work started 5-22-85 /complete	
(9) CONSTRUCTION: Special standards: Yes \(\subseteq \) No \(\mathbb{Z} \) Well seal—Material used	Date well drilling machine moved off of well	5 - 22 ₁₉ 85
Well sealed from land surface to	(unbonded) Water Well Constructor Certifica	tion (if applicable):
Diameter of well bore to bottom of seal	This well was constructed under my direct supe	rvision. Materials used and
Diameter of well bore below seal	information reported above are true to my best kno	wledge and belief.
Amount of sealing material	[Signed] John Mupky	Date 5-22 , 19 85
low was cement grout placed? pressure grouted	(handed) Weter Well Continue Contistentia	
	(bonded) Water Well Constructor Certification Bond 05U452863 Issued by: United	
370	(Number) (Surety Company Name)	
Was pump installed? NO Type HP Depth ft.	(type or print name of Water Wall Constructor)	
Was a drive shoe used? Yes No Plugs Size: location	ft.	
Did any strata contain unusable water?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:	
The state of the s		
Method of sealing strata off	(Signed) (Water Well Constructor)	
(Dated) 5-22-85		
Fravel placed from ft. to ft.	<u> </u>	