

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED

STATE OF OREGON WATER WELL REPORT
OCT 26 1973

RECEIVED

19S/30-24 etc
9S/1E-3E

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

MAR 19 1974

(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Well No.

State Permit No.

(1) OWNER:

Name Edagr D. Arney Well #3
Address 80081 North Turkey Road
Creswell, Oregon

STATE ENGINEER
SALEM, OREGON

1751
LANE

(10) LOCATION OF WELL:

County Lane Driller's well number 2001073D
SW 1/4 SW 1/4 Section 24 T. 19S R. 3W W.M.

Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from +3 ft. to 136 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Torch

Size of perforations 3/16 in. by 12 in.
20 perforations from 80 ft. to 100 ft.
20 perforations from 120 ft. to 136 ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 50 gal./min. with 76 ft. drawdown after 48 hrs.
" " " " " " "
" " " " " " "
Bailer test 60 gal./min. with 30 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m.
Temperature of water 57 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 50 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 28 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 31 ft.
Static level 13 ft. below land surface. Date 9-7-73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 136 ft. Depth of completed well 136 ft.
Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|------|-----|-----|
| Top soil with clay | 0 | 5 | |
| Sub-soil (Sandy) | 5 | 8 | |
| Silt, gravel, and cobble rock | 8 | 22 | 13 |
| Gravel with clay | 22 | 25 | |
| Sandstone; light gray, soft | 25 | 42 | |
| Sandstone; light gray, medium hard | 42 | 47 | |
| Sandstone; gray to green with small gravel | 47 | 65 | |
| Siltstone; gray, soft | 65 | 74 | |
| Siltstone; gray to brown, soft | 74 | 93 | |
| Siltstone; light gray, soft | 93 | 97 | |
| Siltstone; brown with organic matter | 97 | 107 | |
| Siltstone; light gray, soft | 107 | 120 | |
| Sandstone; gray, medium soft | 120 | 136 | |

Work started 8-27 1973 Completed 9-7 1973
Date well drilling machine moved off of well 9-7 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] John Taylor Date 9-10, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 594

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Schoen Electric and Pump
(Person, firm or corporation) (Type or print)
Address 626 W. Queen/Albany, Oregon 97321

[Signed] Larry Schoen
(Water Well Contractor)

Contractor's License No. 513 Date 9-10, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)