

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
JUL 27 1972

STATE OF OREGON
STATE ENGINEER
SALEM, OREGON
(Please type or print)
(Do not write above this line)

LANE

17589

State Well No. 185/4W-29ac
State Permit No.

(1) OWNER:

Name Dr. Lew Myers
Address Route 3, Box 484
Eugene, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☐
6" Diam. from 0 ft. to 21 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

Bailer test 44 gal./min. with 32 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 57 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite YELLOWSTONE
Number of pounds of bentonite per 100 gallons
of water 133 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Lane Driller's well number 303
SE 1/4 NE 1/4 Section 29 T. 18S R. 4W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.
Static level 38 ft. below land surface. Date 7/14/72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	2	
ROCK BROWN	2	11	
ROCK GRAY	11	26	
CLAYSTONE	26	35	
CLAYSTONE - PURPLE	35	63	
GRAY SANDSTONE	63	90	
SANDSTONE GRAY * BLUE	90	144	44
SANDSTONE HARD	144	165	47
SANDSTONE MED	165	200	38

Work started 7/8 1972 Completed 7/14 1972
Date well drilling machine moved off of well 7/14 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] M. P. Budge Date 7/14 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 7417

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Miller-Jensen Company
(Person, firm or corporation) (Type or print)

Address P O Box 2571 Eugene, Or 97402

[Signed] Harry R. Melli Owner
(Water Well Contractor)

Contractor's License No. 179 Date 7-17-72 19