WATER WELL REPORT

STATE OF OREGON

RECEIVED APR 5 1983

LANE

	11
State Well No.	185/5w-laa

WATER RESOURCES DEPTState Permit No.

17834	SALEM, OREGON
1) OWNER:	(10) LOCATION OF WELL:
Name Dick Vandehey	County Lane Driller's well number
Address 90570 Nadeau Rd.	NE 4 NE 4 Section 1 T. 18 ⁸ R. 5W W.M.
	Tax Lot # Lot Blk Subdivision
	Address at well location: Cantrell Rd.
2) TYPE OF WORK (check):	
New Well 😰 Deepening 🗆 Reconditioning 🗆 Abandon 🗆 f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 72 ft.
3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 12 ft. below land surface. Date 3-14-8
Rotary Air D Driven Domestic D Industrial D Municipal D	Artesian pressure lbs. per square inch. Date
Rifery Mud 🗆 Dug 🔲 Irrigation 🗂 Test Well 🗆 Other	(12) WELL LOG: Diameter of well below casing
	Depth drilled 100 ft. Depth of completed well 100 ft.
(5) CASING INSTALLED: Steel XI Plastic X 8"1 H012 100 / Threaded Welded □ 6" Diam. from 26	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
"Diam. from	
(6) PERFORATIONS: Perforated? X Yes D No	Gonsolidated clay/
Type of perforator used 4/// torch	
Size of perforations /////in//in//in.	Soft gray shale/blue &
60	gray 18 24
perforations from	Soft blue/gray shale &
perforations from	CLayC4_4c_
	Soft clay/blue/gray
(7) SCREENS: Well screen installed? 🛣 Yes 🗆 No	shale42_47
Manufacturer's Name	Blue/gray shale & clay 47 78
Type	Blue/gray shale & clay 78 100
Diam Slot Size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
a pump test made? X Yes I No If yes, by whom? driller	
Treld: 30 gal./min. with 43 ft. drawdown after 4 thrs.	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test gal/min. with ft. drawdown after hrs.	
sian flow g.p.m.	
Temperature of water Depth artesian flow encountered	Work started 3_1/ 19 83 Completed 3_18 19
(9) CONSTRUCTION: Special standards: Yes D No D	
Well seal-Material used	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials use
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	(Drilling Machine Operator)
Number of sacks of cement used in well seal	
How was cement grout placed? pressure grout	
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true t
Was pump installed? Type HP Depth ft.	Nomo IIIIO O NOLL DEEE-O
Was a drive shoe used? Yes X No Plugs	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Ves v No	Address 84851 Prodan Lane Pleasant Hill, C
Type of Water? depth of strata	mal 1/401
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? Yes Yes No Size of gravel:	600 1.2
Gravel placed from ft. to	
NOTICE TO WATER WELL CONTRACTOR	WATER RESOURCES DEPARTMENT, SP*12658-63
The original and first copy of this report are to be filed with the	SALEM, OREGON 97310 within 30 days from the date of well completion.