

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED (Copy)
 SEP 25 1964
 STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON (Please type or print)

LANE F8440

State Well No. 18/5W-19
 State Permit No.

(1) OWNER: James B. Coen
 Name
 Address 794
 Clatsop Oregon

(2) LOCATION OF WELL:
 County Lane Driller's well number
 1/4 Section 19 T. 18S R. 5 W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:
 8" Diam. from 0 ft. to 18'4" ft. Gage .250
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:
 Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

(8) SCREENS:
 Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Slot size Set from " ft. to " ft.
 Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal Bentonite
 Depth of seal 18 ft. Was a packer used?
 Diameter of well bore to bottom of seal 9 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from " ft. to " ft.
 Did any strata contain unusuable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off

(10) WATER LEVELS:
 Static level 34 ft. below land surface Date 11-24-62
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
 Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.

Baller test 27 gal./min. with 90 ft. drawdown after 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:
 Diameter of well below casing 8
 Depth drilled 160 ft. Depth of completed well 160 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	1
Clay sand	1	14
Light blue sh	14	60
Grey sandstone	60	160

Work started 11-6 1962 Completed 11-24 1962
 Date well drilling machine moved off of well 11-24 1962

(13) PUMP:
 Manufacturer's Name Berkeley
 Type Sub H.P. 1 1/2

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME Mark Christman (Type of print)
 Address 3550 West 18th
 Drilling Machine Operator's License No. 162
 [Signed] Mark Christman (Water Well Contractor)
 Contractor's License No. 97 Date 11-25 1962