

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED

STATE OF OREGON
(Please type or print)

RECEIVED

State Well No. 20S/3W-32
State Permit No. _____

JUL - 5 1977 (Do not write above this line)

AUG 10 1977

(1) OWNER: WATER RESOURCES DEPT. #2
Name Mr. Gorman Wright SALEM, OREGON
Address 241 Talemana Drive
Cottage Grove, OR 97424

LATE

(10) LOCATION OF WELL: COUNTY SALASAL GRADER'S WELL NUMBER _____
1/4 Section 32 T. 20S R. 3W W.M. _____
Bearing and distance from section or subdivision corner _____

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Cable Dug
Driven Jetted Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED: Threaded Welded
6 " Diam. from 0 ft. to 40 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
_____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" Tested by Air ("Est. could fluctuate") " "
4 1/2 gal./min. with 341 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION: Well seal—Material used Cement
Well sealed from land surface to 39 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? Poured

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 56 ft.
Static level 49 ft. below land surface. Date 6/20/77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 390 ft. Depth of completed well 390 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Yellow brown clay	2	17	
Brown sandy clay	17	32	
Gray sandstone	32	64	
Blue gray sandstone	64	91	
Gray sandstone	91	134	
Blue gray sandstone	134	192	
Gray sandstone	192	261	
Blue gray sandstone	261	291	
Gray sandstone	291	345	
Blue gray sandstone	345	390	

Work started 6/17 19 77 Completed 6/20 19 77
Date well drilling machine moved off of well 6/20 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James L. Smith Date 6/20, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 979

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Casey Jones Well Drilling Co., Inc.
(Person, firm or corporation) (Type or print)
Address 37115 Immigrant Road, Pleasant Hill, OR
[Signed] Casey Jones
(Water Well Contractor)
Contractor's License No. 559 Date 6/20, 19 77