

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT SEP 11 1967

STATE OF OREGON

LANE

18866

18/bw-9D

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER (Please type or print) (Do not write above this line) SALEM, OREGON

State Well No.

State Permit No.

G-4208

(1) OWNER:

Name International Paper Co

Address P.O. Box 308, Veneta, Oregon

(2) TYPE OF WORK (check):

New Well [ ] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

Threaded [ ] Welded [x]

8" Diam. from 0 ft. to 63 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? [ ] Yes [x] No.

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 30 ft. below land surface Date 8-31-67

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [x] No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " " " "

" " " " " "

Baller test 9000 gal./min. with 160 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used Bentonite Clay

Depth of seal 21 ft.

Diameter of well bore to bottom of seal 10 in.

Were any loose strata cemented off? [ ] Yes [x] No Depth

Was a drive shoe used? [ ] Yes [x] No

Did any strata contain unusable water? [ ] Yes [x] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [ ] Yes [x] No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Lane Driller's well number 1/4 1/4 Section 5 T. 18S R. 6W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include Clay with Boulders, Sandstone, Clay, Blue Sandstone, Sandstone & Brown Claystone, Blue Sandstone, Blue Sandstone with Brown Claystone Streaks, Blue Sandstone.

Work started 8-29-67 19 Completed 8-31-67 19

Date well drilling machine moved off of well 8-31-67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Joe Babcock Date 9-5-67, 19

Drilling Machine Operator's License No. 382

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Co Inc (Person, firm or corporation) (Type or print)

Address Route 8 Box 695 Pleasant Hill, Oregon

[Signed] Delbert Jones (Water Well Contractor)

Contractor's License No. 105 Date 9-5-67 19