NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON AUG 1 3 1974 State Well No. 185 10W-12

(Please type or print) STATE ENGINEER_{State Permit N}LANE
(Do not write above this lingALEM, OREGON 19060

(1) OWNER: Gingerbread Village Restaurant	(10) LOCATION OF WELL: # 451
Name % R.P.Gilpin, box 336, Mapleton, Ore.	County Lane Driller's well number 3451
Address	1/4 Section 12 T. 10 R. 18 W.M.
1	Bearing and distance from section or subdivision corner Tie:83 ft.
(2) TYPE OF WORK (check):	9 inches N.76°W from S. corner of garage
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	to well. 76 ft. S. 81 W. from N. corner of gar
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed welgarage to well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 98 to 99 ft.
Cable Z Jetted 🗆 Domestic 📋 industrial 📋 industrial	Static level 41 ft. below land surface. Date 8-6-74
Dug □ Bored □ Irrigation □ Test Well □ Other □	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded	(12) WELL LOG: Diameter of well below casing
6 from 18" a bound 591 ft. Gage 250	
" Diam, from Surf ft. to ft. Gage	Depth drilled 1811 ft. Depth of completed well 1811 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
	with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	brown clay gravel & boulders 10
perforations from ft. to ft.	hard grey sandstone 10 59\frac{1}{2}
perforations from ft. to ft.	grey sandstone 59\$ 98\$
perforations fromft. toft.	grey shale 98 to
	grey sandstone 99 112 99
(7) SCREENS: Well screen installed? Yes No	grey sandstone & some 112
Manufacturer's Name	shale 130 130to
Type Model No,	grey shale 130 132 132
Diam. Slot size Set from ft. to ft.	grey sandstone & some skg 132
Diam. Slot size Set from ft. to ft.	shale 155 155 to
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	grey shale 155 156 156
	grey sandstone & some 156
Was a pump test made? X Yes \(\subseteq \text{No If yes, by whom? driller} \)	shale 173 173 to
yield: 25 gal./min. with 78 ft. drawdown after 7 hrs.	grey shale 173 174 174
" "	grey sandstone & some shall 74
n n n	Lastin Political Control of the Cont
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
perature of water 49 Depth artesian flow encounteredft.	Work started 7-30 19 74 Completed 8-8 19 74
	Date well drilling machine moved off of well 8-9 19 74
(9) CONSTRUCTION:	The state of the s
Well seal-Material usedconcret & sand	Drilling Machine Operator's Certification: This well was constructed under my direct supervision.
Well sealed from land surface toft.	Materials used and information reported above are true to my
Diameter of well bore to bottom of seal1.0. in.	best knowledge and belief.
Diameter of well bore below seal	[Signed] Challenge Machine Operator) Date 8-12, 19.74
Number of sacks of cement used in well sealtwo sacks	Drilling Machine Operator's License No
Number of sacks of bentonite used in well sealNone sacks	Drining Machine Operator's Incense 140.
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of water	true to the best of my knowledge and belief.
Was a drive shoe used? Tyes No Plugs Size: location ft.	Name Charles Panschow, R1, box 192
Did any strata contain unusable water? Yes No	Name Otto: (Type or print) (Type or print)
Type of water? depth of strata	Address Florence, Oregon 97439
Method of sealing strata off	[Signed] Mabel Panschow
Was well gravel packed? Yes No Size of gravel:	(Water Well Contractor)
Change of the state of the stat	Contractor's License No. 87 Date 8-12 19.74